



AKRON REGIONAL
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480
FAX: (330) 375-2402

L. M. Malcolm, P.E.
Administrator

June 1, 2011

Mr. Basem I. Ali
Giant Ohio LLC
1806 N. Franklin Street
Tampa, FL 33602

Dear Mr. Ali:

A representative of the Akron Regional Air Quality Management District (ARAQMD) inspected the following Giant Oil gasoline dispensing facilities to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery:

<u>Date</u>	<u>Site</u>	<u>Address</u>	<u>City</u>
1/12/11	436	571 W. Waterloo Rd.	Akron 1677 010 857
3/16/11	434	1609 Copley Rd.	Akron 1677 010 350
3/21/11	438	3171 S. Arlington Rd.	Akron 1677 000 5 31
3/21/11	432	3705 Cleveland Massillon Rd.	Norton 1677 62 0 111

Inspection results/Deficiencies:

Site Deficiency

- 436 Record keeping: This Agency has not received the results of Stage II testing for 2011. Please submit results immediately. **Giant Oil 436 is in violation of OAC 3745-21-09 (DDD)(2)(c) which requires the results of testing to be submitted within 30 days of tests completion.**
- 438 Record keeping: This Agency has not received the results of Stage II testing for 2011. Please submit results immediately. **Giant Oil 438 is in violation of OAC 3745-21-09 (DDD)(2)(c) which requires the results of testing to be submitted within 30 days of tests completion.**

Please correct the deficiencies noted. This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x3354.

Sincerely,

Harry Eckert
Sanitarian