



AKRON REGIONAL AIR QUALITY MANAGEMENT DISTRICT

Agency of the Ohio Environmental Protection Agency • Division of the Akron Health Department
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480
FAX: (330) 375-2402

Frank J. Markunas
~~E.M. Malcom, P.E.~~
Administrator

April 29, 2010

Mr. Harinderpal Singh
Saini Stores, Inc.
110 Akron Road
Wadsworth, OH 44281

Dear Mr. Singh:

On April 23, 2010, a representative of the Akron Regional Air Quality Management District (ARAQMD) inspected the Convenient Food Mart gasoline dispensing facility located at 110 Akron Road in Wadsworth to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

Inspection results/Deficiencies:

- Record keeping: No record keeping was available for review. **This facility is in violation of OAC rule 3745-21009 (DDD)(3) which requires Stage II record keeping to be available for review.** You must establish a Station file with the required information and obtain a certificate of Stage II training.
- Equipment: **This facility failed Stage II testing on April 23, 2010.** Repair and retesting are to be completed within 30 days.
- ARAQMD file: A review of our records found that you have not applied for transfer of ownership for the Ohio EPA Permit to Operate for this facility. The Ohio EPA Permit to Operate issued to Con Sun Foods is valid until April 16, 2012, and may be transferred to you by submitting the renewal form that I left with Jatinder Saini on April 23, 2010. Submit renewal form immediately. **Failure to obtain an Ohio EPA Permit to Install/Operate is a violation of OAC rule 3745-31-02(A)(1)(c) which requires permit issuance before any air contaminant source can be operated.**

CITICENTER - SUITE 904
146 SOUTH HIGH STREET • AKRON, OHIO 44308
An equal opportunity employer and provider of services - CRA 1964



Printed on Recycled Paper

Mr. Harinderpal Singh
Page 2
April 29, 2010

Please correct the deficiencies noted. This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x6053.

Sincerely,

A handwritten signature in cursive script that reads "Susan Anderson".

Susan Anderson
Sanitarian II

SA