



AKRON REGIONAL
AIR QUALITY MANAGEMENT DISTRICT

*Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department
Serving Medina, Portage and Summit Counties*

TELEPHONE: (330) 375-2480
FAX: (330) 375-2402

L.M. Malcom, P.E.
Administrator

January 8, 2010

Mr. Robert Meszaros
Meszaros Motor Sports
9660 East Center Street
Windham, OH 44288

Dear Mr. Meszaros:

On December 21, 2009, a representative of the Akron Regional Air Quality Management District (ARAQMD) inspected the Meszaros Motor Sports gasoline dispensing facility located at 9660 East Center Street in Windham to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

Inspection results/Deficiencies:

Record keeping: No record keeping was available for review. **This facility is in violation of OAC rule 3745-21009 (DDD)(3) which requires Stage II record keeping to be available for review.** You must establish a station file with the required information and obtain a certificate of Stage II training.

ARAQMD file: This facility was due for Stage II testing on or before October 27, 2009. To date, this Agency has not received test results. **This facility is in violation of OAC rule 3745-21-09 (DDD)(2) which specifies the testing required and its frequency.**

At the time of inspection, you informed the inspector that you may permanently close this gasoline dispensing facility. If this is your intention, you need to contact this Agency to complete the necessary paperwork and remove all hanging hardware from the dispensers immediately.

Acceptance of the information requested by this Agency does not constitute a waiver of this Agency's or the Ohio EPA's authority to seek civil penalties as provided in Section 3704.06 of the Ohio Revised Code. The determination to pursue or decline such penalties will be made at a later date.

CITICENTER - SUITE 904
146 SOUTH HIGH STREET • AKRON, OHIO 44308
An equal opportunity employer and provider of services - CRA 1964



Printed on Recycled Paper

Mr. Robert Meszaros
Page 2
January 8, 2010

This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. **If you have any questions, please contact me at 330/375-2480 x6053.**

Sincerely,



Susan Anderson
Sanitarian II

SA
Certified Mail