

AKRON REGIONAL  
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department  
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480  
FAX: (330) 375-2402

L. M. Malcolm, P.E.  
Administrator

October 7, 2009

Mr. Sukhjinder Singh  
Sarai Petroleum, LLC  
427 N. Court Street  
Medina, OH 44256

Dear Mr. Singh:

On October 6, 2009, a representative of the Akron Regional Air Quality Management District (ARAQMD) inspected the Sarai Marathon gasoline dispensing facility located at 1705 Diagonal Road in Akron to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

**Inspection results/Deficiencies:**

Record keeping: **Sarai Petroleum, LLC is in violation of OAC 3745-21-09 (DDD)(3) which specifies record keeping that is to be kept.** Once again, no record keeping was available for review. A copy of your Ohio EPA Permit to Operate has been enclosed per your request. Create a station file with the required record keeping and explain to site operators that it must be made available at time of inspection. The operators at this location were unwilling to look for record keeping.

ARAQMD file: **This facility is late in completing Stage II testing and is in violation of OAC rule 3745-21-09 (DDD)(2).** Testing is to be completed annually not to exceed 12 months of the previous year's test including the dynamic pressure performance test (blockage test) once every five years. This facility was due for testing by 6/23/09.

Please correct the deficiencies noted. This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.


CITICENTER - SUITE 904  
146 SOUTH HIGH STREET • AKRON, OHIO 44308  
*An equal opportunity employer and provider of services - CRA 1964*

Mr. Sukhjinder Singh  
Page 2  
October 7, 2009

Acceptance of the information requested by this Agency does not constitute a waiver of this Agency's or the Ohio EPA's authority to seek civil penalties as provided in Section 3704.06 of the Ohio Revised Code. The determination to pursue or decline such penalties will be made at a later date.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x6053.

Sincerely,

A handwritten signature in black ink, appearing to read "Susan Anderson", with a long horizontal line extending to the right.

Susan Anderson  
Sanitarian II

SA  
Enclosure  
Certified Mail