



AKRON REGIONAL
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480
FAX: (330) 375-2402

Frank J. Markunas
~~E.M. Maicom, P.E.~~
Administrator

August 5, 2010

Mr. M. Mustafa
Memorial One Stop
PO Box 10082
Akron, OH 44310

Dear Mr. Mustafa:

On July 26, 2010, a representative of the Akron Regional Air Quality Management District (ARAQMD) inspected the Memorial One Stop gasoline dispensing facility located at 215 Memorial Parkway in Akron to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

Inspection results/Deficiencies:

Record keeping: **This facility is in violation of OAC rule 3745-21-09 (DDD)(3)(vi).** Proof of attendance and completion of the training required by the Ohio EPA for the Operator or local manager of the gasoline dispensing facility was not obtained and placed in the Station file. According to Tanknology's records, the final test was never submitted to them for grading and, therefore, a certificate of completion was never mailed to you. Contact Cindy Herzner at 1-800-964-1270.

Equipment: On 7/26/10 this facility was scheduled to complete Stage II vapor recovery testing. Testing was canceled on this date due to equipment repair not completed in time for testing. This facility was due to complete annual Stage II testing on or before 6/12/10. **Memorial One Stop is in violation of the OAC rule 3745-21-09 (DDD)(2)(f).**

Last year's inspection follow-up letter requested that within 30 days of receipt, you were to submit a copy of your Ohio EPA certificate of training to this Agency. To date, you have failed to comply with that request.

CITICENTER - SUITE 904
146 SOUTH HIGH STREET • AKRON, OHIO 44308
An equal opportunity employer and provider of services - CRA 1964



Printed on Recycled Paper

Mr. M. Mustafa
Page 2
August 5, 2010

Acceptance of the actions requested by this Agency does not constitute a waiver of this Agency's or the Ohio EPA's authority to seek civil penalties as provided in Section 3704.06 of the Ohio Revised Code. The determination to pursue or decline such penalties will be made at a later date.

Please correct the deficiencies noted. This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x6053.

Sincerely,



Susan Anderson
Sanitarian II

SA
Certified Mail
cc Jennifer Yasin (at facility)