



AKRON REGIONAL
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480
FAX: (330) 375-2402

Frank J. Markunas
~~Mr. Malcom, P.E.~~
Administrator

July 13, 2010.

Mr. Mahmoud Jaber
Gas Time, USA
745 E. Archwood Avenue
Akron, OH 44306

Dear Mr. Jaber:

On July 2, 2010, a representative of the Akron Regional Air Quality Management District (ARAQMD) inspected the Gas Time, USA (formerly BP Archwood) gasoline dispensing facility located at 745 E. Archwood Avenue in Akron to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

Inspection results/Deficiencies:

- Record keeping: No records were available for review. A certificate of Stage II training must be obtained and a copy kept in the station file. **This facility is in violation of OAC rule 3745-21-09 (DDD)(3) which specifies the records that are to be kept.**
- Equipment: This facility has failed to successfully complete Stage II vapor recovery system testing on or before June 25, 2010. This facility is in violation of **3745-21-09 (DDD)(2) which specifies the testing required and its frequency.** Testing needs to be scheduled immediately.
- ARAQMD file: Our records still identify this facility as BP Archwood. I left copies, at the facility, of the necessary paperwork to transfer the Ohio EPA Permit to Operate to the new Operator and to identify the Owner, Operator, and designated Contact person for this facility. To date, this information has not been received by this Agency. Please submit this information.

CITICENTER - SUITE 904
146 SOUTH HIGH STREET • AKRON, OHIO 44308
An equal opportunity employer and provider of services - CRA 1964

Mr. Mahmoud Jaber
Page 2
July 13, 2010

Please correct the deficiencies noted. This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Acceptance of the actions and information requested by this Agency does not constitute a waiver of this Agency's or the Ohio EPA's authority to seek civil penalties as provided in Section 3704.06 of the Ohio Revised Code. The determination to pursue or to decline such penalties will be made at a later date.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x6053.

Sincerely,



Susan Anderson
Sanitarian II

SA
Certified Mail
cc Tom Kalman, Ohio EPA
Joseph Moneskey