

AKRON REGIONAL  
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department  
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480  
FAX: (330) 375-2402

L. M. Malcolm, P.E.  
Administrator

October 8, 2009

Mr. Amer Alahmad  
3980 N. Pearl Road  
Medina, OH 44256

Dear Mr. Alahmad:

On August 3, 2009, this Agency received notification from Certified Oil Company that the gasoline dispensing facility located at 3980 N. Pearl Road in Medina has been sold to you.


The Ohio EPA Permit to Operate for this facility has expired and must be renewed immediately. The application forms may be obtained on line at <http://www.epa.state.oh.us/dapc/>.

This Facility has Stage II vapor recovery control and is subject to annual testing, inspections, and record keeping requirements per OAC rule 3745-21-09 (DDD). If you are not familiar with the requirements of this rule, please contact me to obtain that information. According to our records, Stage II vapor recovery testing was last successfully performed at this facility on October 2, 2008 and is overdue for testing for 2009. **Testing needs to be scheduled Schedule immediately.** It is important that you maintain your facility in compliance with the above-cited rule.

Enclosed is a flyer that explains EPA regulations that pertain to gasoline dispensing facilities and a list of companies that test Stage II vapor control systems including those that provide Stage II training. The owner/operator must have a certificate of Stage II training along with the required record keeping on-site.

Should you have any questions, please contact me at 330/375-2480 x6053

Sincerely,



Susan Anderson  
Sanitarian II

SA  
Enclosures

CITICENTER - SUITE 904  
146 SOUTH HIGH STREET • AKRON, OHIO 44308  
*An equal opportunity employer and provider of services - CRA 1964*