



AKRON REGIONAL  
**AIR QUALITY MANAGEMENT DISTRICT**

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department  
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480  
FAX: (330) 375-2402

L. M. Malcolm, P.E.  
Administrator

June 22, 2009

Mr. Faisal Mirza  
Ghem Food Mart  
1337 S. Water Street  
Kent, OH 44240

Dear Mr. Mirza:

On June 18, 2009, a representative of the Akron Regional Air Quality Management District (ARAQMD) inspected the Ghem Food Mart gasoline dispensing facility located at 1337 S. Water Street in Kent to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

**Inspection results/Deficiencies:**

- Record keeping: **Ghem Food Mart is in violation of OAC rule 3745-21-09(DDD)(3) which specifies record keeping requirements. The results of Stage II testing completed in 2007 & 2008 were not in the Station file.**
- Equipment: The hoses on dispensers #3, #6, & #7 are damaged and in need of replacement.
- ARAQMD file: According to our records, this facility is late for Stage II vapor recovery testing due in 2009. Schedule testing immediately.

Please correct the deficiencies noted. This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x4255.

Sincerely,

Steven Stakleff, RS  
Sanitarian II

SA

CITICENTER - SUITE 904

146 SOUTH HIGH STREET • AKRON, OHIO 44308

*An equal opportunity employer and provider of services - CRA 1964*