



AKRON REGIONAL  
**AIR QUALITY MANAGEMENT DISTRICT**

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department  
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480  
FAX: (330) 375-2402

L. M. Malcolm, P.E.  
Administrator

March 6, 2009

Ms. Cecy Kinne  
Speedway SuperAmerica, LLC  
PO Box 1500  
Springfield, OH 45501

Dear Ms. Kinne:

On March 3, 2009, a representative of the Akron Regional Air Quality Management District inspected the Speedway SuperAmerica #3661 gasoline dispensing facility located at 317 E. Highland Rd. in Macedonia to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

**Inspection results/Deficiencies:**

Record keeping: **No record keeping was available for review. Speedway SuperAmerica #3661 is in violation of OAC rule 3745-21-09 (DDD)(3) which specifies the record keeping that is to be maintained and available for review. New manager at this location.**

Equipment: **This facility failed Stage II testing on 3/9/09. Repair and retesting are required within 30 days.**

Please correct deficiencies noted. This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x6053.

Sincerely,

Susan Anderson  
Sanitarian II

SA

CITICENTER - SUITE 904  
146 SOUTH HIGH STREET • AKRON, OHIO 44308  
*An equal opportunity employer and provider of services - CRA 1964*