



AKRON REGIONAL  
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department  
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480  
FAX: (330) 375-2402

L. M. Malcolm, P.E.  
Administrator

January 12, 2009

Ms. Cecy Kinne  
Speedway SuperAmerica, LLC  
PO Box 1500  
Springfield, OH 45501

Dear Ms. Kinne:

A representative of the Akron Regional Air Quality Management District (ARAQMD) inspected the following Speedway SuperAmerica gasoline dispensing facilities to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery:

<u>Date</u>	<u>Site</u>	<u>Address</u>	<u>City</u>
1/7/09	9294	3239 Medina Road	Medina
1/7/09	3632	4261 State Route 43	Brimfield
— 1/8/09	3692	3540 S. Arlington Street	Akron
1/9/09	3555	3535 Massillon Road	Uniontown

**Inspection results/Deficiencies:**

<u>Station</u>	<u>Deficiency</u>
3632	Equipment: This facility failed Stage II testing on 1/7/09. Repair and retesting are required within thirty (30) days.
3692	Record keeping: The results of Stage II testing for 2006, 2007, & 2008 were not in the Station file. Equipment: This facility failed Stage II testing on 1/8/09. Repair and retesting is required within thirty (30) days.
3555	Record keeping: No records were available for review. The new manager could not find records. <b>Speedway/SuperAmerica #3555 is in violation of OAC rule 3745-21-09 (DDD) which specifies what record keeping is to be available.</b> Equipment: This facility failed Stage II testing on 1/9/09. Repair and retesting are required within thirty (30) days.

CITICENTER - SUITE 904

146 SOUTH HIGH STREET • AKRON, OHIO 44308

*An equal opportunity employer and provider of services - CRA 1964*

Ms. Cecy Kinne  
Page 2  
January 12, 2009

Please correct the deficiencies noted. These facilities will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x6053.

Sincerely,



Susan Anderson  
Sanitarian II

SA