



AKRON REGIONAL  
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department  
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480  
FAX: (330) 375-2402

L. M. Malcolm, P.E.  
Administrator

August 18, 2009

Mr. Usman Ghandi  
East Avenue Marathon  
4368 Sleepy Hollow Cove  
Lilburn, GA 30047

Dear Mr. Ghandi:

On August 14, 2009, a representative of the Akron Regional Air Quality Management District (ARAQMD) inspected the East Avenue Marathon gasoline dispensing facility located at 2115 East Avenue in Akron to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

**Inspection results/Deficiencies:**

Record keeping: Incomplete record keeping was available for review. **East Avenue Marathon is in violation of OAC rule 3745-21-09 (DDD)(3)(a) which specifies what records are to be maintained.** A certificate of Stage II training must be on-site. Enclosed is a list of testing companies, including those who also provide Stage II training.

Within 30 days of receipt of this letter, you are to establish the required record keeping at this facility and submit a copy of the required certificate of Stage II training to this Agency.

Please correct the deficiencies noted. This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x4255.

Sincerely,

Steven Stakieff, RS  
Sanitarian II

SA  
Enclosure

CITICENTER - SUITE 904  
146 SOUTH HIGH STREET • AKRON, OHIO 44308  
*An equal opportunity employer and provider of services - CRA 1964*