



AKRON REGIONAL
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480
FAX: (330) 375-2402

L.M. Malcom, P.E.
Administrator

November 30, 2009

Mr. Rahif Faris
Waterloo Marathon
598 E. Waterloo Road
Akron, OH 44319

Dear Mr. Faris:

On November 18, 2009, a representative of the Akron Regional Air Quality Management District (ARAQMD) inspected the Waterloo Marathon gasoline dispensing facility located at 598 E. Waterloo Road in Akron to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

Inspection results/Deficiencies:

Record keeping: Incomplete record keeping was available for review. **Waterloo Marathon is in violation of OAC rule 3745-21-09 (DDD)(3)** which requires Stage II record keeping to be available for review. **You must establish a Station file with the required information and obtain a certificate of Stage II training.**

Please correct any deficiencies noted. This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x6053

Sincerely,

Susan Anderson
Sanitarian II

SA

CITICENTER - SUITE 904
146 SOUTH HIGH STREET • AKRON, OHIO 44308
An equal opportunity employer and provider of services - CRA 1964



Printed on Recycled Paper