



AKRON REGIONAL
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480
FAX: (330) 375-2402

L. M. Malcolm, P.E.
Administrator

June 8, 2011

Ms. Claudia Moldovan
Quality Scrub
86 Merz Boulevard
Akron, OH 44333

Dear Ms. Moldovan:

A representative of the Akron Regional Air Quality Management District (ARAQMD) inspected the following Quality Scrub gasoline dispensing facilities to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery:

<u>Date</u>	<u>Site</u>	<u>Address</u>	<u>City</u>
4/28/11	Marathon	61 Ghent Rd. 167700015	Akron
4/28/11	Sunoco	288 Medina Rd. 1652050114	Medina

Inspection results/Deficiencies:

<u>Site</u>	<u>Deficiency</u>
Marathon	Equipment: This facility failed Stage II testing on 4/28/11. Repair and retesting are to be completed within 30 days.
Sunoco	ARAQMD file: The results of Stage II testing completed on 4/28/11 have not been submitted to this Agency. Quality Scrub is in violation of OAC 3745-21-09 (DDD)(2)(c) which requires the results of testing to be submitted within 30 days of tests completion.

CITICENTER - SUITE 904
146 SOUTH HIGH STREET • AKRON, OHIO 44308
An equal opportunity employer and provider of services - CRA 1964

Ms. Claudia Moldovan


Page 2

June 8, 2011

This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x4255.

Sincerely,

A handwritten signature in cursive script that reads "Steve Stakieff" followed by a circled "RS" in the upper right corner.

Steven Stakieff, RS
Sanitarian II