



AKRON REGIONAL
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department
 Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480
 FAX: (330) 375-2402

Frank J. Markunas
~~E. Markunas, P.E.~~
 Administrator

December 17, 2010

Mr. Brian Aiello
 EZ Energy USA, Inc.
 4141 Rockside Road, #400
 Seven Hills, OH 44131

Dear Mr. Aiello:

Our Agency is in receipt of the test results submitted by Crompco for the following EZ Energy BP gasoline dispensing facilities locations:

| <u>Date</u> | <u>Site</u> | <u>Address</u> | <u>City</u> |
|-------------|-------------|------------------|-------------|
| 03/20/01 | 1126 | 15 Pearl Road | Brunswick |
| 03/22/01 | 1116 | 2900 Medina Road | Medina |

Upon review, the test results are accepted as received and will be included in the Operating Files for these facilities. However, **EZ Energy USA, inc. is in violation of OAC 3745-21-09(DDD)(2)(c) which requires Stage II test results to be submitted within 30 days of the test's completion.** All of EZ Energy's 2010 testing was received by this Agency on December 16, 2010.

This Agency has the option to accept or to reject late submittals. Future violations may result in rejection and enforcement action.

Full compliance testing, as conducted at these facilities, must be performed again within five year intervals according to the testing requirements of OAC rule 3745-21-09 (DDD)(2)(a)&(b). The above facilities will be due for **full testing** on or before the date of this year's testing in **2015**. Notification of testing is required as before, as well as reporting requirements.

I would also like to remind you that the Static Leak Test and A/L testing as specified within the CARB Executive Orders and/or this Agency must be performed annually, not to exceed one year from the last test performed. You are required to notify us before testing, and the results of the annual performance test are to be submitted within thirty (30) days of the test's completion.

If you have any questions, please contact me at (330) 375-2480 x6053.

Sincerely,

Susan Anderson
 Sanitarian II

SA

CITICENTER - SUITE 904
 146 SOUTH HIGH STREET • AKRON, OHIO 44308
 An equal opportunity employer and provider of services - CRA 1964