



AKRON REGIONAL
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480
FAX: (330) 375-2402

Frank J. Markunas
~~E.M. Matcom, P.E.~~
Administrator

December 14, 2010

Mr. Ray Fanous
Route 94, Inc.
Ridge Road Marathon
2968 Ridge Road
Medina, OH 44256

Dear Mr. Fanous:

On December 8, 2010, a representative of the Akron Regional Air Quality Management District inspected the Ridge Road Marathon gasoline dispensing facility located at 2968 Ridge Road in Medina to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

Inspection results/Deficiencies:

Record keeping: Incomplete record keeping was available for review. Route 94, Inc. is in violation of OAC rule 3745-21-09 (DDD)(3) which specifies record keeping requirements and its availability. Stage II test results for testing completed in 2007 & 2009 and the post test inspection form for 2008 were missing.

Please correct any deficiencies noted. This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x6053.

Sincerely,

Susan Anderson
Sanitarian II

SA

CITICENTER - SUITE 904
146 SOUTH HIGH STREET • AKRON, OHIO 44308
An equal opportunity employer and provider of services - CRA 1964



Printed on Recycled Paper