



AKRON REGIONAL
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480
FAX: (330) 375-2402

Frank J. Markunas
~~L.V. Maleom, P.E.~~
Administrator

July 30, 2010

Mr. Shinder Sheera
NS Corporation dba Petrol US
8851 Wooster Pike Road
Seville, OH 44273

Dear Mr. Sheera:

On July 22, 2010, a representative of the Akron Regional Air Quality Management District inspected the Petrol US gasoline dispensing facility located at 8851 Wooster Pike Road in Seville to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

Inspection results/Deficiencies:

Record keeping: No records were available for review. **Petro US is in violation of OAC rule 3745-21-09 (DDD)(3), which specifies the records that are to be kept and their availability.** You must obtain a certificate of Stage II training. You were to have established record keeping at the site and obtained a certificate of Stage II training by 8/8/09 per last year's inspection follow-up letter.

Equipment: This facility failed Stage II testing on 7/8/09. **Repair and retesting were not completed within 30 days.** The retesting was successfully completed on 9/1/09.

Correct the deficiencies immediately. This facility will be reinspected within 30 days for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them. Failure to establish required record keeping and obtain Stage II training will cause this Agency to file enforcement action against NS Corporation dba Petrol US.

Acceptance of the corrections requested by this Agency does not constitute a waiver of this Agency's or the Ohio EPA's authority to seek civil penalties as provided in Section 3704.06 of the Ohio Revised Code.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x6053.

Sincerely,

Susan Anderson
Sanitarian II

SA
Certified Mail

CITICENTER - SUITE 904
146 SOUTH HIGH STREET • AKRON, OHIO 44308
An equal opportunity employer and provider of services - CRA 1964