



AKRON REGIONAL
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480
FAX: (330) 375-2402

L. M. Malcolm, P.E.
Administrator

June 23, 2011

1200692219/

Mr. Jason McCain
Pilot Travel Centers LLC
PO Box 10146
Knoxville, TN 37909

Dear Mr. McCain:

Our Agency is in receipt of the 2/1/10, Stage II test results submitted by US Tank for the Seville Pilot station # 0013 gasoline dispensing facility located at 8924 Lake Road in Seville.

Upon review, the test results are accepted as received and will be included in the Operating File for this facility. However, this Agency received the results of Stage II testing on June 13th, 2011. **The Seville Pilot station is in violation of OAC rule 3745-21-09 (DDD)(2)(c) which requires that the results of Stage II testing to be submitted within thirty days following the completion of the tests.**

Full compliance testing, as conducted at this facility, must be performed again within five year intervals according to the testing requirements of OAC rule 3745-21-09 (DDD)(2)(a)&(b). This facility will be due for **full testing** on or before 2/1/15. Notification of testing is required as before, as well as reporting requirements.

I would also like to remind you that the Static Leak Test and A/L test as specified within the CARB Executive Orders and/or by this Agency must be performed annually, not to exceed one year from the last test performed. You are required to notify us before testing, and the results of the annual performance test are to be submitted within thirty (30) days of the test's completion.

If you have any questions, please contact me at (330) 375-2480 x3950.

Sincerely,

Nicole Bradley
Environmental Specialist
CITICENTER - SUITE 904

146 SOUTH HIGH STREET • AKRON, OHIO 44308

An equal opportunity employer and provider of services - CRA 1964



Printed on Recycled Paper