

AKRON REGIONAL  
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department  
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480  
FAX: (330) 375-2402

L. M. Malcolm, P.E.  
Administrator

June 13, 2011

1652 1000 69  
Mr. Brian Logue  
Gillotta, Inc.  
415 Hines Hill  
Hudson, OH 44236

Dear Mr. Logue:

On March 2, 2011, a representative of the Akron Regional Air Quality Management District inspected the 57 Marathon gasoline dispensing facility located at 8775 Wadsworth Road in Wadsworth to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

**Inspection results/Deficiencies:**

ARAQMD file: According to our records, this Agency has not received the results of Stage II testing completed on 3/2/11. Please submit results. **57 Marathon is in violation of OAC 3745-21-09 (DDD)(2)(c) which requires the results of testing to be submitted within 30 days of tests completion.**

Please correct deficiencies noted. This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x4255.

Sincerely,

*Steven Stakleff (SL)*

Steven Stakleff, RS  
Sanitarian II

CITICENTER - SUITE 904  
146 SOUTH HIGH STREET • AKRON, OHIO 44308  
*An equal opportunity employer and provider of services - CRA 1964*