



AKRON REGIONAL
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480
FAX: (330) 375-2402

L. M. Malcolm, P.E.
Administrator

August 13, 2008

Mr. Kevin Merritt
Mac's Convenience Stores, LLC
PO Box 347
Columbus, IN 47202-0347

Dear Mr. Merritt:

On July 31, 2008, a representative of the Akron Regional Air Quality Management District inspected the Circle K #5335 gasoline dispensing facility located at 1051 N. High Street in Wadsworth to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

Inspection results/Deficiencies:

Record keeping: Stage II test results for 2006 were not in the Station file. The Ohio EPA Permit to Operate on file has expired. The Stage II training certificate on file is for an employee no longer employed here. Please obtain a current certificate of training.

ARAQMD file: A review of our records confirmed that the Ohio EPA Permit to Operate for this facility expired on 8/21/06. You were informed of this in a letter dated May 3, 2007. **Ohio Administrative Code section 3745-35-02, requires issuance of a Permit to Operate (PTO) before any air contaminant source can be operated. Ohio Revised Code section 3704.05 prohibits any violation of the Ohio Environmental Protection Agency (Ohio EPA) regulations, and provides for civil and criminal penalties for violations.** A Permit to Operate application may be obtained on-line at <http://www.epa.state.oh.us/dapc/permits> or by contacting this Agency.

Within 15 days of receipt of this letter you are to submit a renewal application for the Ohio EPA Permit to Operate for this facility.


CITICENTER - SUITE 904
146 SOUTH HIGH STREET • AKRON, OHIO 44308
An equal opportunity employer and provider of services - CRA 1964

Mr. Kevin Merritt
Page 2
August 13, 2008

Please correct the deficiencies noted. This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x4255.

Sincerely,

A handwritten signature in black ink, appearing to read 'Stakleff', written in a cursive style.

Steven Stakleff, RS
Sanitarian II

SA
Certified Mail