



AKRON REGIONAL
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480
FAX: (330) 375-2402

L. M. Malcolm, P.E.
Administrator

May 15, 2008

Mr. Kevin Merritt
Mac's Convenience Stores, LLC
PO Box 347
Columbus, IN 47202-0347

Dear Mr. Merritt:

A representative of the Akron Regional Air Quality Management District (ARAQMD) inspected the following Mac's / Circle K gasoline dispensing facilities to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery:

<u>Date</u>	<u>Station</u>	<u>Address</u>	<u>City</u>
5/13/08	5369	1343 Tallmadge Road	Brimfield 1667040117
5/13/08	5599	850 N. Mantua Avenue	Kent 1667040095

Inspection results/Deficiencies:

<u>Station</u>	<u>Deficiency</u>
5369	Record keeping: No record keeping was available for review. Mac's / Circle K is in violation of OAC rule 3745-21-09 (DDD)(3) which specifies the records that are to be kept.
	Equipment: This facility failed Stage II testing on 5/13/08. Timely repair and retesting are required.
5360	Record keeping: The results of Stage II testing for 2006 & 2007 were not in the Station file.
	Equipment: This facility failed Stage II testing on 5/13/08. Timely repair and retesting are required.

CITICENTER - SUITE 904

146 SOUTH HIGH STREET • AKRON, OHIO 44308


An equal opportunity employer and provider of services - CRA 1964

Mr. Kevin Merritt
Page 2
May 15, 2008

Please correct the deficiencies noted. These facilities will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x4255.

Sincerely,

A handwritten signature in black ink, appearing to read "Stakleff", written over a horizontal line.

Steven Stakleff, RS
Sanitarian II

SA