



AKRON REGIONAL  
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department  
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480  
FAX: (330) 375-2402

L. M. Malcolm, P.E.  
Administrator

January 24, 2007

Mr. Thayer Teye  
Tarrify Property's LLC  
9203 Kinsman Road  
Cleveland, OH 44104

Dear Mr. Teye:

On January 10, 2007, a representative of the Akron Regional Air Quality Management District inspected the Kent Clark gasoline dispensing facility located at 706 S. Water Street in Kent to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

**Inspection results/Deficiencies:**

Record keeping: The results of Stage II testing due in 2006 were not in the Station file.

ARAQMD file: A review of our files found that Stage II test results for 2006 were not submitted to this Agency. Please submit the results immediately. **If testing was not completed in 2006, Tarrify Property's LLC is in violation of OAC rule 3745-21-09 (DDD)(2)(f) which requires the vapor recovery system be tested as required by the CARB certification for the Wayne system installed. Further testing violations will cause this Agency to seek enforcement action.**

Please correct any deficiencies noted. This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 ext 4255.

Sincerely,

Steven Stakleff, RS  
Sanitarian II

SS

CITICENTER - SUITE 904  
146 SOUTH HIGH STREET • AKRON, OHIO 44308  
An equal opportunity employer and provider of services - CRA 1964