



AKRON REGIONAL
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480

FAX: (330) 375-2402

June 25, 2010

Frank J. Markunas
~~E.M. Malcom, P.E.~~
Administrator

Mr. Scott Moon
Hop-In
PO Box 1565
Lawrence, OH 30046

Dear Mr. Moon:

A representative of the Akron Regional Air Quality Management District inspected the following Hop-In gasoline dispensing facilities to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery:

<u>Date</u>	<u>Station</u>	<u>Address</u>	<u>City</u>
6/15/10	E. Main Street	1836 E. Main Street	Kent
6/15/10	State Road	2113 State Road	Cuyahoga Falls

Inspection results/Deficiencies:

<u>Station</u>	<u>Deficiency</u>
E. Main	Record keeping: No record keeping was available for review. This facility is in violation of OAC rule 3745-21009 (DDD)(3) which requires Stage II record keeping to be available for review. You must establish a station file with the required information and obtain a certificate of Stage II training.
	Equipment: This facility failed Stage II testing on 6/15/10. Repair and retesting was completed on 6/23/10.
State	Record keeping: No record keeping was available for review. This facility is in violation of OAC rule 3745-21009 (DDD)(3) which requires Stage II record keeping to be available for review. You must establish a station file with the required information and obtain a certificate of Stage II training.

Please correct the deficiencies noted. These facilities will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x4255.

Sincerely,

Steven Stakleff, RS
Sanitarian II

SA

CITICENTER - SUITE 904

146 SOUTH HIGH STREET • AKRON, OHIO 44308

An equal opportunity employer and provider of services - CRA 1964



Printed on Recycled Paper