



AKRON REGIONAL
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480
FAX: (330) 375-2402

Frank J. Markunas
~~Lt. Malcolm H.E.~~
Administrator

December 28, 2010

Mr. Faisal Mirza
IFR Petroleum
Gem Food Mart
1337 S. Water St.
Kent, OH 44240

Dear Mr. Mirza:

Our Agency is in receipt of the October 19, 2010, Stage II test results submitted by Tank Integrity for the IFR Petroleum's Gem Food Mart gasoline dispensing facility located at 1337 S. Water St. in Kent.

Upon review, the test results are accepted as received and will be included in the Operating File for this facility. **However, IFR Petroleum's Gem Food Mart is in violation of OAC 3745-21-09(DDD)(2)(c) which requires the results of Stage II testing to be submitted within 30 days of tests completion.** Test results were received on 12/27/10.

Full compliance testing, as conducted at this facility, must be performed again within five year intervals according to the testing requirements of OAC rule 3745-21-09 (DDD)(2)(a)&(b). The above facility will be due for **full testing** on or before **10/19/15**. Notification of testing is required as before, as well as reporting requirements.

I would also like to remind you that the Static Leak Test and A/L testing as specified within the CARB Executive Orders and/or this Agency must be performed annually, not to exceed one year from the last test performed. You are required to notify us before testing, and the results of the annual performance test are to be submitted within thirty (30) days of the test's completion.

If you have any questions, please contact Steve Stakleff at (330) 375-2480 x4255.

Sincerely,

Susan Anderson
Sanitarian II

SA
faxc Tank Integrity

CITICENTER - SUITE 904
146 SOUTH HIGH STREET • AKRON, OHIO 44308
An equal opportunity employer and provider of services - CRA 1964



Printed on Recycled Paper