



AKRON REGIONAL
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480
FAX: (330) 375-2402

L. M. Malcolm, P.E.
Administrator

September 24, 2008

1667060115
Mr. Jitendra Kapsi
Nilima, Inc. / Valero
527 N. Freedom Street
Ravenna, OH 44266

Dear Mr. Kapsi:

On September 19, 2008, a representative of the Akron Regional Air Quality Management District inspected the Valero gasoline dispensing facility located at 527 N. Freedom Street in Ravenna to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

Inspection results/Deficiencies:

Record keeping: **Nilima, Inc. / Valero is in violation of OAC 3745-21-09 (DDD)(3) which specifies record keeping that is to be kept.** There was not a certificate of Stage II training, Stage II testing results, and maintenance records in the Station file.

Equipment: **This facility is late in completing Stage II testing in accordance with OAC rule 3745-21-09 (DDD)(2).** Testing is to be completed annually, not to exceed 12 months from the previous year's test, including the dynamic pressure performance test (blockage test) once every 5 years. This facility was due on or before 2/24/08. **On 9/19/08 this facility failed Stage II vapor recovery testing. Timely repair and retesting are required.** Failure to complete testing as required may result in this Agency seeking enforcement action.

Within 15 days of receipt of this letter you are to obtain a certificate of Stage II training, establish the required record keeping on site, and make arrangements for repair and retesting of the Stage II vapor control equipment at this location.

CITICENTER - SUITE 904

146 SOUTH HIGH STREET • AKRON, OHIO 44308

An equal opportunity employer and provider of services - CRA 1964



Printed on Recycled Paper

Mr. Jitendra Kapsi
Page 2
September 24, 2008

Please correct any deficiencies noted. This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x6053.

Sincerely,



Susan Anderson
Sanitarian II

SA
Certified Mail