



AKRON REGIONAL  
**AIR QUALITY MANAGEMENT DISTRICT**

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department  
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480  
FAX: (330) 375-2402

Frank J. Markunas  
~~L.M. Malcom, P.E.~~  
Administrator

December 28, 2010

Mr. Harpreet Aujla  
BDS Ravenna Clark  
800 S. Prospect  
Ravenna, Ohio 44266

Dear Mr. Aujla:

Our Agency is in receipt of the January 27, 2010, Stage II test results submitted by Tank Integrity for the BDS Ravenna Clark gasoline dispensing facility at 800 S. Prospect in Ravenna.

Upon review, the test results are accepted as received and will be included in the Operating File for this facility. **However, BDS Ravenna Clark is in violation of OAC 3745-21/09(DDD)(2)(c) which requires the results of Stage II testing to be submitted within 30 days of tests completion.** These results were received on 12/27/10.

Full compliance testing, as conducted at this facility, must be performed again within five year intervals according to the testing requirements of OAC rule 3745-21-09 (DDD)(2)(a)&(b). This facility will be due for **full testing** on or before **1/27/15**. Notification of testing is required as before, as well as reporting requirements.

I would also like to remind you that the Static Leak Test and A/L testing as specified within the CARB Executive Orders and/or this Agency must be performed annually, not to exceed one year from the last test performed. You are required to notify us before testing, and the results of the annual performance test are to be submitted within thirty (30) days of the test's completion.

If you have any questions, please contact me at (330) 375-2480 x6053.

Sincerely,

Susan Anderson  
Sanitarian II

SA  
faxc Tank Integrity

CITICENTER - SUITE 904  
146 SOUTH HIGH STREET • AKRON, OHIO 44308  
*An equal opportunity employer and provider of services - CRA 1964*