



# AKRON REGIONAL AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department  
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480  
FAX: (330) 375-2402

Frank J. Markunas  
~~Lt. Mayor, P.E.~~  
Administrator

September 13, 2010

Mr. Mike Scheponik  
Echo Development for Giant Eagle, Inc.  
101 Kappa Drive  
RIDC Park  
Pittsburgh, PA 15238

Dear Mr. Scheponik:

A representative of the Akron Regional Air Quality Management District (ARAQMD) inspected the following Giant Eagle - Get Go gasoline dispensing facilities to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery:

<u>Date</u>	<u>Site</u>	<u>Address</u>	<u>City</u>
9/7/10	3620	1711 Corporate Woods Circle	Uniontown
9/8/10	3299	265 E. Highland Road	Macedonia
9/9/10	3348	909 E. Main Street	Ravenna

### Inspection results/Deficiencies:

<u>Site</u>	<u>Deficiency</u>
3299	Record Keeping: No record keeping was available for review. <b>This facility is in violation of OAC rule 3745-21-09 (DDD)(3) which requires Stage II record keeping to be available for review.</b>

Please correct any deficiencies noted. These facilities will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x6053.

Sincerely,

Susan Anderson  
Sanitarian II

SA

CITICENTER - SUITE 904  
146 SOUTH HIGH STREET • AKRON, OHIO 44308  
An equal opportunity employer and provider of services - CRA 1964