



AKRON REGIONAL
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480
FAX: (330) 375-2402

Frank J. Markunas
~~L. M. Malecom, P.E.~~
Administrator

June 8, 2010

Mr. Mohamed Tayeb
On the Go Gas
10498 Northfield Road
Northfield, OH 44067

Dear Mr. Tayeb:

Our Agency is in receipt of the April 26, 2010, Stage II test results submitted by ECT for the On the Go Gas gasoline dispensing facility located at 10498 Northfield Road in Northfield.

Upon review, the test results are accepted as received and will be included in the Operating File for this facility. **However, On the Go Gas is in violation of OAC rule 3745-21-09 (DDD)(2)(c) which requires that the results of Stage II testing to be submitted to the Ohio EPA or its delegated local air agency within thirty days following the completion of the tests.** The test results for this location were received June 2, 2010. Full compliance testing, as conducted at this facility, must be performed again within five year intervals according to the testing requirements of OAC rule 3745-21-09 (DDD)(2)(a)&(b). This facility will be due for **full testing** on or before **4/26/15**. Notification of testing is required as before, as well as reporting requirements.

I would also like to remind you that the Static Leak Test, and A/L testing as specified within the CARB Executive Orders and/or by this Agency must be performed annually, not to exceed one year from the last test performed. You are required to notify us before testing, and the results of the annual performance test are to be submitted within thirty (30) days of the test's completion.

If you have any questions, please contact me at (330) 375-2480 x6053.

Sincerely,

Susan Anderson
Sanitarian II

SA
cc Anwer Latif

CITICENTER - SUITE 904
146 SOUTH HIGH STREET • AKRON, OHIO 44308
An equal opportunity employer and provider of services - CRA 1964



Printed on Recycled Paper