

AKRON REGIONAL
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480
FAX: (330) 375-2402

L. M. Malcolm, P.E.
Administrator

June 17, 2011

1677600534
Mr. Joseph Moneskey
Gas & Oil, Inc.
1256 Krumroy Road
Akron, OH 44306

Mr. Elian (Nick) Zayed
Attn: Karen
1980 S. Arlington St.
Akron, OH 44306

Dear Messrs. Moneskey & Zayed:

On April 8, 2011, a representative of the Akron Regional Air Quality Management District (ARAQMD) inspected the Gas & Oil #7 (operated by Kiss Oil, Inc.) gasoline dispensing facility located at 1980 S. Arlington Street in Akron to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

Inspection results/Deficiencies:

Record keeping: No record keeping was available for review. **This facility is in violation of OAC rule 3745-21009 (DDD)(3) which requires Stage II record keeping is available for review.** You must establish a Station file with the required information and obtain a certificate of Stage II training. Record keeping is to be kept at the site and available for inspection.

ARAQMD file: According to our records this facility failed to complete Stage II testing in 2010. Gas & Oil #7 (operated by Kiss Oil, Inc.) is in violation of **OAC rule 3745-21-09 (DDD)(2) which specifies the testing required and its frequency.** If testing was completed in 2010, please submit results immediately.

Also, the **Ohio EPA Permit to Operate** for this facility will expire on **6/26/11**. Enclosed with this application is a Permit by Rule Notification Form and instructions. Please complete this form and return to this Agency at 146 S. High St. Suite 904, Akron, OH 44308 as soon as possible.

CITICENTER - SUITE 904

146 SOUTH HIGH STREET • AKRON, OHIO 44308

An equal opportunity employer and provider of services - CRA 1964



Printed on Recycled Paper

Mr. Joseph Monesky
Mr. Elian (Nick) Zayed
Page 2
June 17, 2011

Please correct the deficiencies noted. This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Acceptance of the record keeping , 2010 Stage II test results & permit renewal requested by this Agency does not constitute a waiver of this Agency's or the Ohio EPA's authority to seek civil penalties as provided in Section 3704.06 of the Ohio Revised Code. The determination to pursue or to decline such penalties will be made at a later date.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x3354.

Sincerely,



Harry J. Eckert
Environmental Specialist

Certified Mail
e-mail c Tom Kalman, Ohio EPA
Sarah Bloom, Ohio Attorney General