



AKRON REGIONAL  
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department  
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480  
FAX: (330) 375-2402

L. M. Malcolm, P.E.  
Administrator

January 24, 2007

1677000591  
Mrs. Missy Cotterman  
Speedway SuperAmerica, LLC  
PO Box 1500  
Springfield, OH 45501

Dear Mrs. Cotterman:

On January 18, 2007, a representative of the Akron Regional Air Quality Management District inspected the Speedway SuperAmerica #3633 gasoline dispensing facility located at 1275 Canton Road in Akron to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

**Inspection results/Deficiencies:**

Record keeping: The results of Stage II testing and post test forms for 2004, 2005, & 2006 were not in the Station file. **Speedway SuperAmerica #3633 is in violation of OAC rule 3745-21-09 (DDD) which specifies what record keeping is to be available.**

Please correct any deficiencies noted. This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 ext 4255.

Sincerely,

Steven Stakleff, RS  
Sanitarian II

SS

CITICENTER - SUITE 904  
146 SOUTH HIGH STREET • AKRON, OHIO 44308  
An equal opportunity employer and provider of services - CRA 1964