

AKRON REGIONAL
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480
FAX: (330) 375-2402

L. M. Malcolm, P.E.
Administrator

October 21, 2008

1677 616 765
Mr. Sukhjinder Singh
Sarai Petroleum, LLC
427 N. Court Street
Medina, OH 44256

Dear Mr. Singh:

On October 3, 2008, a representative of the Akron Regional Air Quality Management District (ARAQMD) inspected the Sarai Marathon gasoline dispensing facility located at 1705 Diagonal Road in Akron to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

Inspection results/Deficiencies:

- Record keeping: **Sarai Petroleum, LLC is in violation of OAC 3745-21-09 (DDD)(3) which specifies the record keeping that is to be kept. No record keeping was available for review.**
- Equipment: The hose on dispenser #2 is damaged and must be replaced.
- ARAQMD file: **This facility is late in completing Stage II testing and is in violation of OAC rule 3745-21-09 (DDD)(2). Testing is to be completed annually, not to exceed 12 months of the previous year's test, including the dynamic pressure performance test (blockage test) once every 5 years. This facility was due for testing by 6/23/08. This Agency has received notice of testing scheduled for this facility on 10/30/08. All required testing must be successfully passed and the results submitted to this Agency no more than 30 days following the test's completion.**

CITICENTER - SUITE 904

146 SOUTH HIGH STREET • AKRON, OHIO 44308

An equal opportunity employer and provider of services - CRA 1964



Printed on Recycled Paper

Mr. Sukhjinder Singh

Page 2

October 21, 2008

Please correct the deficiencies noted. This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Acceptance of the information requested by this Agency does not constitute a waiver of this Agency's or the Ohio EPA's authority to seek civil penalties as provided in Section 3704.06 of the Ohio Revised Code. The determination to pursue or decline such penalties will be made at a later date.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x6053.

Sincerely,



Susan Anderson
Sanitarian II

SA
Certified Mail