



AKRON REGIONAL
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480
FAX: (330) 375-2402

Frank J. Markunas
~~L.M. Matcom, P.E.~~
Administrator

October 7, 2010

Mr. Mazen Alhijawi
Star Gas
1404 S. Main Street
Akron, OH 44301

Dear Mr. Alhijawi:

Our Agency is in receipt of the June 25, 2010, Stage II test results submitted by Tank Integrity for the Best Gas gasoline dispensing facility located at 1404 S. Main Street in Akron.

Upon review, the test results are accepted as received and will be included in the Operating File for this facility. **However, Best Gas is in violation of OAC rule 3745-21-09 (DDD)(2)(c) which requires that the results of Stage II testing to be submitted to the Ohio EPA or its delegated local air agency within thirty days following the completion of the tests.** The test results for this location were received October 4, 2010.

Full compliance testing, as conducted on this date, must be performed again within five year intervals according to the testing requirements of OAC rule 3745-21-09 (DDD)(2)(a)(b)(c)(d). This facility will be due for **full testing** on or before **6/25/15**. Notification of testing is required as before, as well as reporting requirements.

I would also like to remind you that the Static Leak Test and A/L test as specified within the CARB Executive Orders and/or by this Agency must be performed annually, not to exceed one year from the last test performed. You are required to notify us before testing, and the results of the annual performance test are to be submitted within thirty (30) days of the test's completion.

If you have any questions, please contact me at 330/375-2480 x6053.

Sincerely,

Susan Anderson
Sanitarian II

SA
faxc Tank Integrity

CITICENTER - SUITE 904
146 SOUTH HIGH STREET • AKRON, OHIO 44308
An equal opportunity employer and provider of services - CRA 1964