



AKRON REGIONAL AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480
FAX: (330) 375-2402

L. M. Malcolm, P.E.
Administrator

August 16, 2011

Mr. Ramzi Shalash
Gas & Save.
863 W Exchange St.
Akron, Ohio 44302

Dear Mr. Shalash:

On August 12, 2011, a representative of the Akron Regional Air Quality Management District (ARAQMD) inspected the Gas & Save gasoline dispensing facility located at 863 W. Exchange Street in Akron to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

Inspection results/Deficiencies:

- Record keeping: No maintenance records were available for review. **This facility is in violation of OAC rule 3745-21009 (DDD)(3) which requires Stage II record keeping is available for review.** Record keeping is to be kept at the site and available for inspection.
- Equipment: **The following equipment was damaged and must be replaced within 30 days.** Pump number one the faceplate and bellows was torn. Pump number two the hose was damaged at the retractor and must be kept out of service until replaced.

Please correct the deficiencies noted. This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Acceptance of the record keeping and Stage II testing requested by this Agency does not constitute a waiver of this Agency's or the Ohio EPA's authority to seek civil penalties as provided in Section 3704.06 of the Ohio Revised Code. The determination to pursue or to decline such penalties will be made at a later date.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x3950.

Sincerely,

Nicole Bradley
Nicole Bradley
Environmental Specialist

CITICENTER - SUITE 904

146 SOUTH HIGH STREET • AKRON, OHIO 44308

An equal opportunity employer and provider of services - CRA 1964

1677010785