



AKRON REGIONAL
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480
FAX: (330) 375-2402

L. M. Malcolm, P.E.
Administrator

February 21, 2007

1677010835
Mr. Kevin Merritt
Mac's Convenience Stores, LLC
315 Commons Mall
Columbus, IN 47201

Dear Mr. Merritt:

On February 13, 2007, a representative of the Akron Regional Air Quality Management District (ARAQMD) inspected the Circle K #5612 gasoline dispensing facility located at 1281 Copley Road in Akron to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

Inspection results/Deficiencies:

ARAQMD file: According to our records this facility failed to pass Stage II vapor recovery testing in 2006. Mac's Convenience Stores, LLC is in violation of OAC rule 3745-21-09 (DDD)(1)(b) and the CARB certification G-70-150 AE for the Gilbarco vapor recovery system installed at this location.

Please correct any deficiencies noted. This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x4255.

Sincerely,

Steven Stakleff, RS
Sanitarian II

SS
Certified Mail

CITICENTER - SUITE 904
146 SOUTH HIGH STREET • AKRON, OHIO 44308
An equal opportunity employer and provider of services - CRA 1964