

AKRON REGIONAL
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480
FAX: (330) 375-2402

L. M. Malcolm, P.E.
Administrator

October 16, 2008

167761083
Mr. M. Mustafa
PO Box 10082
Akron, OH 44310

Dear Mr. Mustafa:

On September 29, 2008, a representative of the Akron Regional Air Quality Management District (ARAQMD) inspected the Memorial One Stop gasoline dispensing facility located at 215 Memorial Parkway in Akron to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

Inspection results/Deficiencies:

Record keeping: **This facility is in violation of OAC rule 3745-21-09 (DDD)(3)(vi).** Proof of attendance and completion of the training required by the Ohio EPA for the Operator or local manager of the gasoline dispensing facility was not obtained and placed in the Station file.

ARAQMD file: **This facility is in violation of OAC rule 3745-21-09 (DDD)(2).** Testing is to be completed annually, not to exceed 12 months of the previous year's test, including the dynamic pressure performance test (blockage test) once every 5 years. This facility did not complete testing in 2005 or 2007, and is late completing testing for 2008. **On 10/6/08, this facility failed Stage II vapor recovery testing and has rescheduled testing for 10/22/08.** Submit test results within 30 days of test's completion.

Acceptance of the information requested by this Agency does not constitute a waiver of this Agency's or the Ohio EPA's authority to seek civil penalties as provided in Section 3704.06 of the Ohio Revised Code. The determination to pursue or decline such penalties will be made at a later date.


CITICENTER - SUITE 904
146 SOUTH HIGH STREET • AKRON, OHIO 44308
An equal opportunity employer and provider of services - CRA 1964

Mr. M. Mustafa
Page 2
October 16, 2008

This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact Susan Anderson at 330/375-2480 x6053.

Yours truly,



L. M. Malcolm, PE
Administrator

SA
Certified Mail
cc Jennifer Yasin (facility)