



AKRON REGIONAL  
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department  
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480  
FAX: (330) 375-2402

L. M. Malcolm, P.E.  
Administrator

August 13, 2008

1677616809  
Mr. Usman Ghandi  
Clark Mart  
4368 Sleepy Hollow Cove  
Lilburn, GA 30047

Dear Mr. Ghandi:

On August 5, 2008, a representative of the Akron Regional Air Quality Management District (ARAQMD) inspected the Clark Mart gasoline dispensing facility located at 2115 East Avenue in Akron to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

**Inspection results/Deficiencies:**

- Record keeping: No record keeping was available for review. **Clark Mart is in violation of OAC rule 3745-21-09 (DDD)(3)(a) which specifies the records that are to be maintained.** A certificate of Stage II training must be at the site.
- Equipment: **This facility failed Stage II testing on 8/5/08.** Timely repair and retesting are required.
- ARAQMD file: In a letter from this Agency dated August 24, 2007, you were required to submit, in writing, what had been done to correct the violations at this station. **To date, this Agency has not received a response from you.** This facility was due to have completed Stage II testing by 7/28/08 and is therefore late. **Testing is required annually. Immediate attention is needed regarding repair and retesting.**

Please correct the deficiencies noted. This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.


CITICENTER - SUITE 904  
146 SOUTH HIGH STREET • AKRON, OHIO 44308  
An equal opportunity employer and provider of services - CRA 1964

Mr. Usman Ghandi  
Page 2  
August 13, 2008

Acceptance of the information requested by this Agency does not constitute a waiver of this Agency's or the Ohio EPA's authority to seek civil penalties as provided in Section 3704.06 of the Ohio Revised Code. The determination to pursue or decline such penalties will be made at a later date.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x4255.

Sincerely,

A handwritten signature in black ink, appearing to read 'Stakleff', written over a horizontal line.

Steven Stakleff, RS  
Sanitarian II

SA  
Certified Mail