



AKRON REGIONAL  
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department  
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480  
FAX: (330) 375-2402

L. M. Malcolm, P.E.  
Administrator

August 22, 2011

Ms. Harjeet Singh  
2115 East Ave.  
Akron, Ohio 44314

Dear Mr. Singh

On August 11, 2011, a representative of the Akron Regional Air Quality Management District inspected the Marathon gasoline dispensing facility at 2115 East Ave in Akron to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

**Inspection results/Deficiencies:**

Record keeping: Record keeping was incomplete. The results of the Stage II testing completed in 2008 were not in the station file. **This facility is in violation of OAC rule 3745-21009 (DDD)(3) which requires Stage II record keeping is available for review.** You must obtain a certificate of Stage II training. Record keeping is to be kept at the site and available for inspection.

Please correct any deficiencies noted. This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x3950.

Sincerely,

*Nicole Bradley*  
Nicole Bradley  
Environmental Specialist

CITICENTER - SUITE 904  
146 SOUTH HIGH STREET • AKRON, OHIO 44308  
An equal opportunity employer and provider of services - CRA 1964

1677010809