



AKRON REGIONAL  
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department  
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480  
FAX: (330) 375-2402

L. M. Malcolm, P.E.  
Administrator

January 24, 2007

1677010193  
Mr. Ahmed Harajli  
Fusion Oil/ ~~Jet Fuel~~, Inc. C6460  
34501 Grant Street  
Romulus, MI 48174

Dear Mr. Harajli:

On January 5, 2007, a representative of the Akron Regional Air Quality Management District inspected the Cuyahoga Gas & Go, Inc. gasoline dispensing facility located at 2816 State Road in Cuyahoga Falls to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

**Inspection results/Deficiencies:**

Record keeping: The results of Stage II testing for 2006 and a certificate of Stage II training were not in the Station file.

ARAQMD file: A review of our records found that the results of Stage II testing for 2006 have not been submitted. **OAC rule 3745-21-09 (DDD)(2)(c) requires that the results of Stage II testing be submitted to the Ohio EPA or its delegated local air agency within thirty days following the completion of the tests.**

Please correct any deficiencies noted. This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 ext 4255.

Sincerely,

Steven Stakleff, RS  
Sanitarian II

SS

CITICENTER - SUITE 904  
146 SOUTH HIGH STREET • AKRON, OHIO 44308  
An equal opportunity employer and provider of services - CRA 1964