



AKRON REGIONAL  
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency - Division of the Akron Health Department  
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480  
FAX: (330) 375-2402

L. M. Malcolm, P.E.  
Administrator

June 8, 2011

Mr. Husam Abdelqader  
YAFA Gas, Inc.  
Bailey Road Mini Mart  
2810 Bailey Road  
Cuyahoga Falls, OH 44221

1677050156

Dear Mr. Abdelqader:

On March 30, 2011, a representative of the Akron Regional Air Quality Management District (ARAQMD) inspected the Bailey Road Mini Mart gasoline dispensing facility located at 2810 W. Bailey Road to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

**Inspection results/Deficiencies:**

**Record keeping:** No record keeping was available for review. This facility is in violation of OAC rule 3745-21009 (DDD)(3) which requires Stage II record keeping to be available for review. You must establish a station file with the required information and obtain a certificate of Stage II training. This deficiency was cited at last years inspection.

**ARAQMD file:** A review of our records found that you have an Ohio EPA Permit to Install & Operate. This Permit is eligible for transfer to Permit by Rule (PBR). Enclosed with this application is the form necessary to change how you are permitted. Submit this form to this Agency to become PBR.

**Within 30 days of receipt of this letter**, you are to submit to this Agency proof of Stage II training and to establish a record keeping file at the station.

Please correct any deficiencies noted. This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x4255.

Sincerely,

Steven Stakleff, RS  
Sanitarian II

CITICENTER - SUITE 904

146 SOUTH HIGH STREET • AKRON, OHIO 44308

An equal opportunity employer and provider of services - CRA 1964



Printed on Recycled Paper