



AKRON REGIONAL
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480
FAX: (330) 375-2402

L. M. Malcolm, P.E.
Administrator

April 29, 2009

Mr. Anwer M. Latif
Pro-Tech Fuel, Inc.
930 Bristol Lane
Streetsboro, OH 44241

Dear Mr. Latif:

On April 24, 2009, a representative of the Akron Regional Air Quality Management District inspected the Pro-Tech Fuel, Inc. gasoline dispensing facility located at 10498 Akron-Cleveland Road in Northfield to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

Inspection results/Deficiencies:

Record keeping: No record keeping was available for review as the facility was not open. **OAC rule 3745-21-09 (DDD)(3) specifies the record keeping that is to be maintained and available for review. You must obtain a certificate of Stage II vapor recovery training right away if it hasn't been done.**

Equipment: This facility failed Stage II testing on 4/24/09. Repair and retesting are to be completed within 30 days.

Please correct the deficiencies noted. This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x6053.

Sincerely,

Susan Anderson
Sanitarian II

SA

CITICENTER - SUITE 904
146 SOUTH HIGH STREET • AKRON, OHIO 44308
An equal opportunity employer and provider of services - CRA 1964