



City of Cleveland
Frank G. Jackson, Mayor

Department of Public Health
Division of Air Quality
75 Erieview Plaza, Second Floor
Cleveland, Ohio 44114-1839
216/664-2297 • Fax: 216/420-8047
www.clevelandhealth.org

SERVING OHIO EPA AS AGENCY 13
FOR CUYAHOGA COUNTY

CERTIFIED MAIL 7011 3500 0000 1759 6061
RETURN RECEIPT REQUESTED

September 13, 2012

Sam Abdelqader
Harvard Friends, LLC.
17510 Harvard Ave
Cleveland, Ohio 44128

FACILITY ID: 1318006162

**RESOLUTION OF VIOLATIONS
NOTICE OF VIOLATION FOLLOW-UP LETTER**

Dear Mr. Abdelqader:

On August 10, 2012, the Cleveland Division of Air Quality (CDAQ) issued a Notice of Violation requiring Harvard Friends, LLC. (Harvard) to submit two weeks of record keeping for maintenance and weekly inspection forms and submit city permit fees for 2010 and 2011.

CDAQ is in receipt of the record keeping for maintenance and weekly inspection forms and the city permit fees for 2010 and 2011 on September 5, 2012.

The corrective action plan was received in a timely manner and appropriate steps were taken to bring the source into compliance. CDAQ has determined that no further enforcement action is warranted at this time, but reserves its right to take such action in the future if necessary.

CDAQ issues this letter with Ohio EPA's concurrence and does not excuse any violations of local, state and federal laws or regulations regarding air pollution control. Violations of air pollution control laws may be pursued in local court or referred to Ohio EPA or U.S. EPA for further enforcement action. Should you have any questions, please call Mike Samec at 216-420-7682. All correspondence with CDAQ must include the Ohio EPA facility identification number for Harvard Friends, LLC. : 1318006162.

Sincerely,

A handwritten signature in black ink that reads "Valencia White".

Valencia White
Chief of Enforcement, CDAQ

VW/ms *LK*



cc: John Paulian, Ohio EPA Central Office
William MacDowell, U.S. EPA Region V
L:\Data\Facilities\1318006162\2012-07-26 ROV + NEAR.docx



Company Name:
Address:

HARVARD SUNOCO
17510 HARVARD AVE
CLEVELAND, OH 44122

Technical Guidance Document


Mo./Year: 1/2012

Weekly Inspection - Vapor Recovery System

* Place initials of the inspector in the spaces provided *

	Week 1							Week 2							Week 3							Week 4							Week 5						
	Sun	Mon	Tues	Wed	Thur	Fri	Sat	Sun	Mon	Tues	Wed	Thur	Fri	Sat	Sun	Mon	Tues	Wed	Thur	Fri	Sat	Sun	Mon	Tues	Wed	Thur	Fri	Sat	Sun	Mon	Tues	Wed	Thur		
Hoses - not crimped, severed, or flattened, etc...	✓							✓							✓							✓													
Nozzles - shut-off device working, spout not loose, cracked	✓							✓							✓							✓													
Nozzle Bellows / Vapor Shroud - good condition	✓							✓							✓							✓													
Swivels - working properly, no vapor/liquid leaks	✓							✓							✓							✓													
Dispenser - no liquid/vapor leaks	✓							✓							✓							✓													
Breakaways - securely attached, not leaking vapor/liquid	✓							✓							✓							✓													
Equipment Verification - no missing labels or stickers	✓							✓							✓							✓													
Underground Tanks - all caps in place, cap seals okay	✓							✓							✓							✓													
Tank Area - spill bucket drained; PV vent cap in place	✓							✓							✓							✓													

Note repairs, maintenance, and service performed (include date, time, type of repair, etc...):
on 8/22/11 w...
the nozzle on pump is leaking
the work



**This form is a technical guidance document only and does not constitute legal advice. Compliance with the law is the facility owner and operator's responsibility.

DIVISION OF AIR QUALITY

