



**Environmental  
Protection Agency**

John E. Kasich, Governor  
Mary Taylor, Lt. Governor  
Mark A. Kelly, Director

September 24, 2012

RE: **NOTICE OF VIOLATION**  
**FAILURE TO COMPLETE REQUIRED**  
**STAGE II TESTING**  
**REDI GO FOOD MART**  
**DAPC FACILITY ID: 024311123**

**CERTIFIED MAIL**

Steve Mikolsky  
Redi Go Food Mart  
7941 Ravenna Rd.  
Concord Twp., OH 44077

Dear Mr. Mikolsky:

This letter inform you that Redi Go Food Mart, located at 7941 Ravenna Rd., Concord Twp., Ohio, has violated the Stage II testing requirements found in Ohio Administrative Code (OAC) Rule 3745-21-09(DDD).

Stage II testing was conducted at this station on July 16, 2012. The station passed the static leak portion of the testing but failed the air-to-liquid ratio testing for all four dispensers. As of the date of this letter, no retest has been scheduled.

Please schedule a retest as soon as possible, but **no later than within seven days of receipt of this letter**. In other words, testing should occur as soon as the testing firm and our office can work out a date, but the act of scheduling the testing should be done within seven days.

Failure to comply with the above request may result in an enforcement action up to and including referral to the Central Office of Ohio EPA for appropriate action.

The submission of the requested information does not constitute a waiver of Ohio EPA's authority to seek civil penalties as provided in ORC 3704.06. Ohio EPA will decide whether to pursue or decline to pursue penalties regarding this matter at a later date.

If you have any questions regarding this letter, please do not hesitate to contact me at (330) 963-1270.

Sincerely,

Tim Fischer  
Environmental Supervisor  
Division of Air Pollution Control

TF:bo

pc: Bruce Weinberg, DAPC, CO  
Bill MacDowell, USEPA, Region V