City of Cleveland
Frank G. Jackson, Mayor

Department of Public Health
Division of Air Quality
75 Erieview Plaza, Second Floor
Cleveland, Ohio 44114-1839
216/664-2297 • Fax: 216/420-8047
www.clevelandhealth.org

**SERVING OHIO EPA AS AGENCY 13
FOR CUYAHOGA COUNTY**

**CERTIFIED MAIL 7011 3500 0000 1759 9796
RETURN RECEIPT REQUESTED**

October 16, 2012

Scott Kollab
One Stop Sunoco
14714 Detroit Avenue
Lakewood, OH 44107

**FACILITY ID: 13-18-39-6635
NOTICE OF VIOLATION: FAILING STAGE II TESTING**

Dear Mr. Kollab:

On October 11, 2012, the Cleveland Division of Air Quality (CDAQ) inspected and witnessed Stage II Testing performed by Environmental Compliance Technologies at One Stop Sunoco #3 located at 11209 State Road in North Royalton. This letter serves as notification that you are operating sources in violation of the following applicable air statutes, air regulations, or air permit conditions.

CDAQ has determined that One Stop Sunoco #3 failed a Static Leak Test as stipulated in Ohio Administrative Code (OAC) Rule 3745-21-09(DDD)(2) on emission unit G001: Stage I and Stage II Gasoline Dispensing Facility. This is a violation of Permit-to-Install #13-04086, Ohio Administrative Code Rules 3745-31-05(A)(3) and 3745-21-09(DDD)(1)(c), and Ohio Revised Code Sections 3704.05(C) and (G).

Unless you undertake some type of corrective action with respect to the above noted violations, you will remain in non-compliance. CDAQ requests that One Stop Sunoco #3 make all necessary repairs, perform a re-test and forward the re-test results within thirty (30) days of your receipt of this letter to the following enforcement representative:

Andrew Marantides
Cleveland Division of Air Quality
75 Erieview Plaza 2nd Floor
Cleveland, Ohio 44114-1839

Your written response to this letter must be received by CDAQ within thirty (30) days of your receipt of this letter. If there is insufficient time to correct the alleged violations within this timeframe, your response must include a timeline for correcting the alleged violations.

Violations of Ohio air pollution laws and /or permit terms and conditions are subject to the penalties stipulated in Ohio Revised Code Section 3704.99(A), which allows fines of not more than twenty-five thousand dollars or imprisonment for not more than one year, or both, for each violation.

CDAQ issues this letter with Ohio EPA's concurrence. The failure to mention any specific violation does not excuse any violations of local, state and federal laws or regulations regarding air pollution control. Violations of air pollution control laws may be pursued in local court or referred to Ohio EPA or U.S. EPA for further enforcement action.

Should you have any questions, please call Andrew Marantides at (216) 420-8049. All correspondence with CDAQ must include the Ohio EPA facility identification number for One Stop Sunoco #3: 13-18-39-6635.

Sincerely,

Valencia White

Valencia White
Chief of Enforcement, CDAQ
VW/AM LK

cc: George P. Baker, CDAQ
Michael J. Krzywicki, CDAQ
John Paulian, Ohio EPA Central Office
William MacDowell, U.S. EPA Region V
L:\Data\Facilities\1318396635\2012-10-11 NOV.docx