



City of Cleveland
Frank G. Jackson, Mayor

Department of Public Health
Division of Air Quality
75 Erievue Plaza, Second Floor
Cleveland, Ohio 44114-1839
216/664-2297 • Fax: 216/420-8047
www.clevelandhealth.org

**SERVING OHIO EPA AS AGENCY 13
FOR CUYAHOGA COUNTY**

**CERTIFIED MAIL 7011 3500 0000 1759 9802
RETURN RECEIPT REQUESTED**

October 17, 2012

Farid Mohammad
Two Great Lake, Inc.
4030 East 131st Street
Cleveland, OH 44105

NON-HIGH PRIORITY FACILITY

**FACILITY ID: 13-18-00-7711
NOTICE OF VIOLATION: FAILING STAGE II TESTING**

Dear Mr. Mohammad:

On October 8, 2012, the Cleveland Division of Air Quality (CDAQ) received Stage II test results from Environmental Compliance Technologies showing that Two Great Lake, Inc. located at 4030 East 131st Street in Cleveland failed an Air-to-Liquid Ratio Test on emission unit G001: Stage I and Stage II Gasoline Dispensing Facility on pump #4. This letter serves as notification that you are operating sources in violation of the following applicable air statutes, air regulations, or air permit conditions.

CDAQ has determined that Two Great Lake, Inc. failed an Air-to-Liquid Ratio Test (A/L) on pump #4 as stipulated in Ohio Administrative Code (OAC) Rule 3745-21-09(DDD)(2). This is a violation of Ohio Administrative Code Rule 3745-21-09(DDD)(1)(c) and Ohio Revised Code Section 3704.05(G).

Unless you undertake some type of corrective action with respect to the above noted violation, you will remain in non-compliance. CDAQ requests that Two Great Lake, Inc. make the necessary repairs to pump #4, perform an A/L re-test on pump #4, and forward the re-test results within thirty (30) days of receipt of this letter to the following enforcement representative:

Andrew Marantides
Cleveland Division of Air Quality
75 Erievue Plaza 2nd Floor
Cleveland, Ohio 44114-1839



Your written response to this letter must be received by CDAQ within thirty (30) days of your receipt of this letter. If there is insufficient time to correct the alleged violations within this timeframe, your response must include a timeline for correcting the alleged violations.

Violations of Ohio air pollution laws and /or permit terms and conditions are subject to the penalties stipulated in Ohio Revised Code Section 3704.99(A), which allows fines of not more than twenty-five thousand dollars or imprisonment for not more than one year, or both, for each violation.

CDAQ issues this letter with Ohio EPA's concurrence. The failure to mention any specific violation does not excuse any violations of local, state and federal laws or regulations regarding air pollution control. Violations of air pollution control laws may be pursued in local court or referred to Ohio EPA or U.S. EPA for further enforcement action.

Should you have any questions, please call Andrew Marantides at (216) 420-8049. All correspondence with CDAQ must include the Ohio EPA facility identification number for Two Great Lake, Inc.: 13-18-00-7711.

Sincerely,

A handwritten signature in cursive script, appearing to read 'Valencia White'.

Valencia White
Chief of Enforcement, CDAQ
VW/AMW

cc: Mohammad Albelbisi, Two Great Lake, Inc.
George P. Baker, CDAQ
Michael J. Krzywicki, CDAQ
John Paulian, Ohio EPA Central Office
William MacDowell, U.S. EPA Region V
L:\Data\Facilities\1318007711\2012-10-17 NOV.docx