

November 8, 2012

CERTIFIED MAIL - RETURN RECEIPT REQUESTED

Mark Zatlokowicz
DTE St. Bernard, LLC
5189 Spring Grove Avenue
Cincinnati, OH 45217

Re: Notice of Violation – Excess Carbon Monoxide (CO) Emissions
Facility ID: 1431394148
Emissions Unit: B045
Facility Name: DTE St. Bernard, LLC
Location: 5189 Spring Grove Avenue
Cincinnati, Ohio 45217
Hamilton County

Dear Mr. Zatlokowicz,

The purpose of this letter is to rescind the NOV for excess carbon monoxide emissions dated October 9, 2012. Most of the excess emissions occurred during startup of emission unit B045, therefore are excluded in accordance with Part III, Term and Condition A.2.2.e. of Permit to Install number 14-05541. This term and condition was not listed in the Preliminarily Proposed Title V renewal permit which was the document that was referenced during the issuance of the NOV. The exclusion of this term and condition from the Title V renewal permit was an oversight by this agency and will be corrected prior to the issuance of your Final Title V permit.

Should you have any questions, please contact me at (513) 946-7709.

Sincerely,


Thomas P. Wittekind
Environmental Compliance Specialist

ec: Bruce Weinberg, Ohio EPA
Brian Dickens, USEPA