



**City of Cleveland**  
Frank G. Jackson, Mayor

Department of Public Health  
Division of Air Quality  
75 Erieview Plaza, Second Floor  
Cleveland, Ohio 44114-1839  
216/664-2297 • Fax: 216/420-8047  
www.clevelandhealth.org

**SERVING OHIO EPA AS AGENCY 13  
FOR CUYAHOGA COUNTY**

**CERTIFIED MAIL 7012 2210 0000 5209 2520  
RETURN RECEIPT REQUESTED**

March 1, 2013

Scott Kollab  
Owner  
One Stop Sunoco #2  
14714 Detroit Avenue, #204  
Lakewood, Ohio 44107

**FACILITY ID: 13-18-00-7056**

**RESOLUTION OF VIOLATIONS  
NOTICE OF VIOLATION FOLLOW-UP LETTER**

Dear Mr. Kollab:

On October 8, 2012, the Cleveland Division of Air Quality (CDAQ) witnessed annual Stage II compliance testing at One Stop Sunoco #2 located at 4402 Lorain Avenue in Cleveland.

On November 23, 2012, CDAQ issued a Notice of Violation (NOV) requesting that One Stop Sunoco #2 make the necessary repairs to emissions unit (EU) G001: Gasoline Dispensing Facility with Stage II controls, then re-test the Dynamic Pressure, Static Leak and Air-to-Liquid Ratio, and submit the test results within 30 days of receipt of the NOV.

CDAQ granted an extension to January 1, 2013, in a Receipt of Corrective Action Plan letter, dated November 30, 2012, to complete the necessary repairs and perform a re-test of the Stage II vapor recovery system.

On December 26, 2012, One Stop Sunoco #2 performed and passed Static Leak and Dynamic Pressure testing; however, the Air-to-Liquid Ratio test could not be performed on pumps 3 and 4 due to the vacuum motors not functioning properly.

CDAQ issued a Second Receipt of Corrective Action on January 9, 2013, requesting that One Stop Sunoco #2 schedule and conduct the required Air-to-Liquid Ratio test on pumps 3 and 4 within 14 days of receipt of the letter.

On February 12, 2013, CDAQ issued a Third Receipt of Corrective Action Plan requiring One Stop Sunoco to schedule and conduct A/L Ratio test on pumps 3 and 4.



On March 1, 2013, CDAQ received passing A/L Ratio tests results on pumps 3 and 4. The tests were conducted on February 14, 2013.

Appropriate steps were taken to bring your gasoline dispensing facility into compliance. CDAQ has determined that no further enforcement action is warranted at this time, but reserves its right to take such action in the future if necessary.

CDAQ issues this letter with Ohio EPA's concurrence and does not excuse any violations of local, state and federal laws or regulations regarding air pollution control. Violations of air pollution control laws may be pursued in local court or referred to Ohio EPA or U.S. EPA for further enforcement action. Should you have any questions, please call Valerie Shaffer at (216) 664-6292. All correspondence with CDAQ must include the Ohio EPA facility identification number for One Stop Sunoco #2: 13-18-00-7056.

Sincerely,

A handwritten signature in cursive script that reads "Valencia White".

Valencia White  
Chief of Enforcement, CDAQ

VW/vls *ll*

cc: One Stop Sunoco #2, 4402 Lorain Avenue, Cleveland, Ohio 44113  
John Paulian, Ohio EPA Central Office  
Brian Dickens, U.S. EPA Region V  
L:\Data\Facilities\1318007056\2012-10-08 ROV+NEAR.docx