



City of Cleveland
Frank G. Jackson, Mayor

Department of Public Health
Division of Air Quality
75 Erievue Plaza, Second Floor
Cleveland, Ohio 44114-1839
216/664-2297 • Fax: 216/420-8047
www.clevelandhealth.org

**SERVING OHIO EPA AS AGENCY 13
FOR CUYAHOGA COUNTY**

**CERTIFIED MAIL 70113500000017598584
RETURN RECEIPT REQUESTED**

April 9, 2013

Ed Szalankiewicz
7-Eleven, Inc.
1140 Center Church Rd.
New Castle, PA 16101-6314

**RE: 7-Eleven No. 36237, 1035 East 185th Street, Cleveland, Ohio
FACILITY ID: 13-18-00-6913**

**RESOLUTION OF VIOLATIONS
NOTICE OF VIOLATION FOLLOW-UP LETTER**

Dear Mr. Szalankiewicz:

On February 21, 2013, the Cleveland Division of Air Quality (CDAQ) witnessed Stage II testing at 7-Eleven No. 36237, located at 1035 East 185th Street in Cleveland. During the Stage II testing, pump #14 failed the Air to Liquid (A/L) Ratio test.

On March 6, 2013, CDAQ issued a Notice of Violation requiring 7-Eleven No. 36237 to schedule and retest the A/L Ratio test on pump #14. As of April 1, 2013, CDAQ is in receipt of passing A/L Ratio test results for pump #14. The retest was conducted on March 22, 2013.

The corrective action plan was received in a timely manner and appropriate steps were taken to bring your gasoline dispensing facility into compliance. CDAQ has determined that no further enforcement action is warranted at this time, but reserves its right to take such action in the future if necessary.

CDAQ issues this letter with Ohio EPA's concurrence and does not excuse any violations of local, state and federal laws or regulations regarding air pollution control. Violations of air pollution control laws may be pursued in local court or referred to Ohio EPA or U.S. EPA for further enforcement action. Should you have any questions, please call Roman Fedorko at 216-664-4794. All correspondence with CDAQ must include the Ohio EPA facility identification number for 7-Eleven No. 36237: 13-18-00-6913.

Sincerely,

Valencia White
Chief of Enforcement, CDAQ

VW/rf



cc: 7-Eleven No. 36237, 1035 East 185th St., Cleveland, OH 44119
John Paulian, Ohio EPA Central Office
Brian Dickens, U.S. EPA Region V
L:\Data\Facilities\1318006913\2013-03-06 ROV+NEAR.docx