

BEFORE THE  
OHIO ENVIRONMENTAL PROTECTION AGENCY

OHIO E.P.A.

JAN 29 2010

In the Matter of:

Roger Ketchum  
dba Ketchum Campground  
dba Hockingport Mobile Home Park  
P.O. Box 551  
Hockingport, OH 45739  
  
Respondent

ENTERED DIRECTOR'S JOURNAL  
Director's Final Findings  
and Orders

I certify this to be a true and accurate copy of the  
official documents as filed in the records of the Ohio  
Environmental Protection Agency.

PREAMBLE

*Michael Shapiro* Date: 1/29/10

It is agreed by the Parties hereto as follows:

I. JURISDICTION

These Director's Final Findings and Orders ("Orders") are issued pursuant to the authority vested in the Director of the Ohio Environmental Protection Agency ("Ohio EPA") under Ohio Revised Code ("ORC") §§ 6111.03 and 3745.01, to Roger Ketchum, P.O. Box 551, Hockingport, Ohio, ("Respondent"), dba Ketchum Campground ("Campground") and Hockingport Mobile Home Park ("MHP").

II. PARTIES BOUND

These Orders shall apply to and be binding upon Respondent and heirs and successors in interest liable under Ohio law. No change in the ownership or the operation of the Campground and/or MHP shall in any way alter Respondent's obligations under these Orders.

III. DEFINITIONS

Unless otherwise stated, all terms used in these Orders shall have the same meaning as defined in ORC Chapter 6111. and the rules adopted thereunder.

IV. FINDINGS

The Director of Ohio EPA has made the following findings:

*Campground*

1. Respondent owns and operates the Campground which has a wastewater treatment plant ("Campground WWTP") located on the north side of Township Road 161, a half mile northwest of the Township Road 161 and State Route 124 intersection, Troy Township, Hockingport, Athens County.

2. The Campground WWTP, pursuant to Ohio National Pollutant Discharge Elimination System ("NPDES") permit OPR00592\*CD ("Campground permit"), effective April 1, 2006, discharges to the Hocking River, which is a water of the state.
3. The Campground WWTP consists of a trash trap, extended aeration, dosing, surface sand filter and chlorination, and discharges through outfall 001, with an average flow of 5,000 gpd.
4. The key parameters limited in the Campground permit are CBOD5, Chlorine Total Residual, Dissolved Oxygen, Fecal Coliform, Nitrogen, Ammonia (NH3) and Total Suspended Solids.

#### *MHP*

5. Respondent owns and operates the MHP, which has a wastewater treatment plant ("MHP WWTP") located at 711 State Route 114, Hockingport, Athens County.
6. The MHP WWTP, pursuant to NPDES permit OPV00014\*CD ("MHP permit"), effective September 1, 2006, discharges to an unnamed tributary of the Ohio River, which is a water of the state.
7. The MHP WWTP consists of a trash trap, flow equalization, aeration, fixed media, sludge holding, dosing, surface sand filter and effluent lift station, and discharges through Outfall 001 which has an average flow of 15,600 gpd.
8. The key parameters limited in the MHP permit are CBOD5, Chlorine Total Residual, Dissolved Oxygen, Fecal Coliform, Nitrogen, Ammonia (NH3) and Total Suspended Solids.

#### *Inspections*

9. On May 1, 2007, memorialized in a letter dated June 26, 2007, Ohio EPA inspected the Campground and MHP and observed or noted the following at both:
  - a. Respondent was to submit permit to install applications for the installation of dechlorination units by 1998;
  - b. The trash traps appeared to be nearly full of solids and required to be pumped out by a licensed septic hauler on a routine basis; and
  - c. Violations of effluent limit and monitoring frequency requirements.
10. February 6, 2008, Ohio EPA met with Respondent regarding violations of the Campground permit and MHP permit. The following items were discussed and agreements reached:

- a. Permit to install applications for the dechlorination units at the Campground and MHP were to be submitted by March 10, 2008, with the units installed no later than May 1, 2008; and
  - b. A report was to be submitted by March 10, 2008, addressing the effluent limit violations and providing, at a minimum, possible causes for the violations and suggested operational and/or equipment changes to eliminate future violations.
11. The report described in Finding No. 10 has not been submitted. Permit to install ("PTI") Application No. 654637 for the Campground's dechlorination unit and PTI No. 654636 for the MHP's dechlorination unit were received on April 25, 2008 and issued on May 16, 2008.
  12. The effluent limit violations since October 2, 2006 are set forth in Attachment 1, for the MHP and Attachment 2, for the Campground. Both Attachments are attached hereto and incorporated herein as if fully rewritten herewith.
  13. ORC § 6111.04(A), in pertinent part, provides that no person shall cause pollution or place or caused to be placed any sewage, sludge, sludge materials, industrial waste, or other wastes in a location where they cause pollution of any waters of the state, unless that person holds a valid, unexpired permit or renewal of a permit.
  14. ORC § 6111.04(C) provides that no person to whom a permit has been issued shall place or discharge, or cause to be placed or discharged, in any waters of the state, any sewage, sludge, sludge materials, industrial waste, or other wastes in excess of the permissive discharges specified under an existing permit.
  15. ORC § 6111.07(A) provides that no person shall violate or fail to perform any duty imposed by ORC §§ 6111. 01 to 6111. 08 or violate any order, rule, or term or condition of a permit issued or adopted by the Director of Ohio EPA pursuant to those sections. Each day of violation is a separate offense.
  16. Permit to Install No. 727475, issued to Respondent on October 22, 2009, addressed the installation and operation of a force main and grinder pump station for residences at 799 and 805 State Route 124, in order that said residences be connected to the MHP WWTP.
  17. In a letter dated October 27, 2009, Respondent informed Ohio EPA that Respondent plans to install a flow equalization system at the Campground by the spring of 2010, and is of the opinion that the total cost will be approximately \$10,000 to \$11,000.
  18. The Director has given consideration to, and based his determination on evidence related to the technical feasibility and economic reasonableness of complying with these Orders and to evidence relating to conditions calculated to result from

compliance with these Orders, and its relation to the benefits to the people of the state to be derived from such compliance in accomplishing the purposes of ORC Chapter 6111.

#### V. ORDERS

1. Respondent shall achieve and maintain compliance with its Campground permit and MHP permit as expeditiously as practicable, but not later than the dates developed in accordance with the following schedule:
  - a. Within two (2) months after the effective date of these Orders, Respondent shall submit to Ohio EPA in accordance with Section X of these Orders, a complete and approvable permit to install application and detailed plans to construct a flow equalization system at the Campground.
  - b. Respondent shall submit revisions to the permit to install application and detailed plans within thirty (30) days of receipt of notification of deficiencies from Ohio EPA. Revisions shall be submitted to Ohio EPA in accordance with Section X. of these Orders.
  - c. By May 1, 2010, Respondent shall have the flow equalization system operational.
2. Within thirty (30) days after the flow equalization system is operational, Respondents shall submit to Ohio EPA in accordance with Section X of these Orders, an itemized accounting of the total cost for said system.
3. Within six (6) months after the effective date of these Orders, Respondent shall comply in totality with the requirements of Permit to Install No. 727475.

#### VI. TERMINATION

Respondent's obligations under these Orders shall terminate when Respondent certifies in writing and demonstrates to the satisfaction of Ohio EPA that Respondent has performed all obligations under these Orders and the Chief of Ohio EPA's Division of Surface Water acknowledges, in writing, the termination of these Orders. If Ohio EPA does not agree that all obligations have been performed, then Ohio EPA will notify Respondent of the obligations that have not been performed, in which case Respondent shall have an opportunity to address any such deficiencies and seek termination as described above.

The certification shall contain the following attestation: "I certify that the information contained in or accompanying this certification is true, accurate and complete."

This certification shall be submitted by Respondent to Ohio EPA and shall be signed by a responsible official of the Respondent. For purposes of these Orders, a responsible official is as defined in OAC Rule 3745-33-03 for a municipal, state, or other public facility.

#### **VII. OTHER CLAIMS**

Nothing in these Orders shall constitute or be construed as a release from any claim, cause of action or demand in law or equity against any person, firm, partnership or corporation, not a party to these Orders, for any liability arising from, or related to activities occurring on or at the Facility.

#### **VIII. OTHER APPLICABLE LAWS**

All actions required to be taken pursuant to these Orders shall be undertaken in accordance with the requirements of all applicable local, state and federal laws and regulations. These Orders do not waive or compromise the applicability and enforcement of any other statutes or regulations applicable to Respondent.

#### **IX. MODIFICATIONS**

These Orders may be modified by agreement of the parties hereto. Modifications shall be in writing and shall be effective on the date entered in the journal of the Director of Ohio EPA.

#### **X. NOTICE**

Unless otherwise specified herein, all documents required to be submitted by Respondent pursuant to these Orders shall be addressed to:

Ohio Environmental Protection Agency  
Southeast District Office  
2195 Front Street  
Logan, Ohio 43138  
(ATTN: Enforcement Supervisor)

#### **XI. RESERVATION OF RIGHTS**

Ohio EPA and Respondent each reserve all rights, privileges and causes of action, except as specifically waived in Section XII of these Orders.

#### **XII. WAIVER**

In order to resolve disputed claims, without admission of fact, violation or liability, and in lieu of further enforcement action by Ohio EPA for only the violations specifically cited in these Orders, Respondent consents to the issuance of these Orders and agrees to comply with these Orders. Compliance with these Orders shall be a full accord and satisfaction for Respondent's liability for the violations specifically cited herein.

Respondent hereby waives the right to appeal the issuance, terms and conditions, and service of these Orders, and Respondent hereby waives any and all rights Respondent may have to seek administrative or judicial review of these Orders either in law or equity.

Notwithstanding the preceding, Ohio EPA and Respondent agree that if these Orders are appealed by any other party to the Environmental Review Appeals Commission, or any court, Respondent retains the right to intervene and participate in such appeal. In such an event, Respondent shall continue to comply with these Orders notwithstanding such appeal and intervention unless these Orders are stayed, vacated or modified.


**XIII. EFFECTIVE DATE**

The effective date of these Orders is the date these Orders are entered into the Ohio EPA Director's journal.

**XIV. SIGNATORY AUTHORITY**

Each undersigned representative of a party to these Orders certifies that he or she is fully authorized to enter into these Orders and to legally bind such party to these Orders.

**IT IS SO ORDERED AND AGREED:  
Ohio Environmental Protection Agency**


  
\_\_\_\_\_  
Chris Korleski  
Director

1/28/10  
Date

**IT IS SO AGREED:  
Roger Ketchum**

  
\_\_\_\_\_  
Signature

1/18/10  
Date

  
\_\_\_\_\_  
Printed or Typed Name

  
\_\_\_\_\_  
Title

Attachment 1

Get New Data

Permit No.	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
0PV00014*CD	January 2007	001	00530	Total Suspended Solids	30D Conc	12	17.	1/1/2007
0PV00014*CD	January 2007	001	00610	Nitrogen, Ammonia (NH3)	1D Conc	3	28.12	1/2/2007
0PV00014*CD	January 2007	001	00610	Nitrogen, Ammonia (NH3)	1D Conc	3	20.57	1/15/2007
0PV00014*CD	January 2007	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2	24.345	1/1/2007
0PV00014*CD	January 2007	001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.18	.36416	1/2/2007
0PV00014*CD	January 2007	001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.18	.26639	1/15/2007
0PV00014*CD	January 2007	001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.16	.31528	1/1/2007
0PV00014*CD	January 2007	001	80082	CBOD 5 day	1D Conc	15	25.	1/2/2007
0PV00014*CD	January 2007	001	80082	CBOD 5 day	30D Conc	10	25.	1/1/2007
0PV00014*CD	January 2007	001	00300	Dissolved Oxygen	1D Conc	6	4.3	1/2/2007
0PV00014*CD	March 2007	001	00610	Nitrogen, Ammonia (NH3)	1D Conc	3	14.22	3/19/2007
0PV00014*CD	March 2007	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2	7.335	3/1/2007
0PV00014*CD	March 2007	001	00300	Dissolved Oxygen	1D Conc	6	5.4	3/5/2007
0PV00014*CD	October 2006	001	50060	Chlorine, Total Residu	1D Conc	.019	.48	10/2/2006
0PV00014*CD	October 2006	001	50060	Chlorine, Total Residu	1D Conc	.019	.38	10/16/2006
0PV00014*CD	April 2008	001	00300	Dissolved Oxygen	1D Conc	6	5.7	4/21/2008
0PV00014*CD	September 2008	001	31616	Fecal Coliform	30D Conc	1000	2967.	9/1/2008
0PV00014*CD	September 2008	001	31616	Fecal Coliform	7D Conc	2000	2967.	9/1/2008
0PV00014*CD	April 2007	001	00530	Total Suspended Solids	1D Conc	18	40.	4/2/2007
0PV00014*CD	April 2007	001	00530	Total Suspended Solids	30D Conc	12	40.	4/1/2007
0PV00014*CD	April 2007	001	00610	Nitrogen, Ammonia (NH3)	1D Conc	3	20.85	4/2/2007
0PV00014*CD	April 2007	001	00610	Nitrogen, Ammonia (NH3)	1D Conc	3	3.74	4/16/2007
0PV00014*CD	April 2007	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2	12.295	4/1/2007
0PV00014*CD	April 2007	001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.18	.26871	4/2/2007
0PV00014*CD	April 2007	001	80082	CBOD 5 day	1D Conc	15	26.	4/2/2007
0PV00014*CD	April 2007	001	80082	CBOD 5 day	30D Conc	10	26.	4/1/2007
0PV00014*CD	April 2007	001	00300	Dissolved Oxygen	1D Conc	6	2.4	4/2/2007
0PV00014*CD	October 2008	001	50060	Chlorine, Total Residu	1D Conc	.019	.23	10/2/2008
0PV00014*CD	October 2008	001	50060	Chlorine, Total Residu	1D Conc	.019	.08	10/15/2008
0PV00014*CD	June 2008	001	31616	Fecal Coliform	30D Conc	1000	1982.	6/1/2008
0PV00014*CD	June 2008	001	50060	Chlorine, Total Residu	1D Conc	.019	.06	6/2/2008
0PV00014*CD	June 2008	001	00300	Dissolved Oxygen	1D Conc	6	4.3	6/2/2008
0PV00014*CD	March 2008	001	00300	Dissolved Oxygen	1D Conc	6	4.8	3/19/2008

0PV00014*CD	July 2008	001	50060	Chlorine, Total Residu	1D Conc	.019	.26	7/2/2008
0PV00014*CD	July 2008	001	50060	Chlorine, Total Residu	1D Conc	.019	.19	7/16/2008
0PV00014*CD	July 2008	001	00300	Dissolved Oxygen	1D Conc	6	5.3	7/16/2008
0PV00014*CD	May 2008	001	00610	Nitrogen, Ammonia (NH3	1D Conc	1.5	16.59	5/20/2008
0PV00014*CD	May 2008	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1	8.395	5/1/2008
0PV00014*CD	May 2008	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.09	.22078	5/20/2008
0PV00014*CD	May 2008	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.06	.11172	5/1/2008
0PV00014*CD	May 2008	001	31616	Fecal Coliform	30D Conc	1000	3567.	5/1/2008
0PV00014*CD	May 2008	001	31616	Fecal Coliform	7D Conc	2000	3567.	5/1/2008
0PV00014*CD	May 2008	001	50060	Chlorine, Total Residu	1D Conc	.019	.12	5/5/2008
0PV00014*CD	August 2008	001	50060	Chlorine, Total Residu	1D Conc	.019	.15	8/11/2008
0PV00014*CD	August 2008	001	50060	Chlorine, Total Residu	1D Conc	.019	.05	8/25/2008
0PV00014*CD	May 2007	001	00610	Nitrogen, Ammonia (NH3	1D Conc	1.5	23.76	5/7/2007
0PV00014*CD	May 2007	001	00610	Nitrogen, Ammonia (NH3	1D Conc	1.5	15.24	5/21/2007
0PV00014*CD	May 2007	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1	19.5	5/1/2007
0PV00014*CD	May 2007	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.09	.2962	5/7/2007
0PV00014*CD	May 2007	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.09	.18999	5/21/2007
0PV00014*CD	May 2007	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.06	.24309	5/1/2007
0PV00014*CD	May 2007	001	50060	Chlorine, Total Residu	1D Conc	.019	.21	5/7/2007
0PV00014*CD	May 2007	001	50060	Chlorine, Total Residu	1D Conc	.019	.08	5/21/2007
0PV00014*CD	May 2007	001	00300	Dissolved Oxygen	1D Conc	6	5.6	5/7/2007
0PV00014*CD	May 2007	001	00300	Dissolved Oxygen	1D Conc	6	4.4	5/21/2007
0PV00014*CD	October 2007	001	00300	Dissolved Oxygen	1D Conc	6	5.5	10/1/2007
0PV00014*CD	June 2007	001	00610	Nitrogen, Ammonia (NH3	1D Conc	1.5	17.18	6/4/2007
0PV00014*CD	June 2007	001	00610	Nitrogen, Ammonia (NH3	1D Conc	1.5	8.26	6/18/2007
0PV00014*CD	June 2007	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1	12.72	6/1/2007
0PV00014*CD	June 2007	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.09	.27768	6/4/2007
0PV00014*CD	June 2007	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.09	.1335	6/18/2007
0PV00014*CD	June 2007	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.06	.20559	6/1/2007
0PV00014*CD	June 2007	001	31616	Fecal Coliform	30D Conc	1000	1634.	6/1/2007
0PV00014*CD	June 2007	001	50060	Chlorine, Total Residu	1D Conc	.019	.06	6/4/2007
0PV00014*CD	June 2007	001	00300	Dissolved Oxygen	1D Conc	6	3.4	6/4/2007
0PV00014*CD	June 2007	001	00300	Dissolved Oxygen	1D Conc	6	2.3	6/18/2007
0PV00014*CD	July 2007	001	00610	Nitrogen, Ammonia (NH3	1D Conc	1.5	11.9	7/2/2007
0PV00014*CD	July 2007	001	00610	Nitrogen, Ammonia (NH3	1D Conc	1.5	18.98	7/18/2007
0PV00014*CD	July 2007	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1	15.44	7/1/2007
0PV00014*CD	July 2007	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.09	.18201	7/2/2007

OPV00014*CD	July 2007	001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.09	.2903	7/18/2007
OPV00014*CD	July 2007	001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.06	.23616	7/1/2007
OPV00014*CD	July 2007	001	50060	Chlorine, Total Residu	1D Conc	.019	.34	7/2/2007
OPV00014*CD	July 2007	001	00300	Dissolved Oxygen	1D Conc	6	5.	7/2/2007
OPV00014*CD	July 2007	001	00300	Dissolved Oxygen	1D Conc	6	3.	7/16/2007
OPV00014*CD	September 2007	001	50060	Chlorine, Total Residu	1D Conc	.019	.56	9/4/2007
OPV00014*CD	August 2007	001	00610	Nitrogen, Ammonia (NH3)	1D Conc	1.5	19.05	8/6/2007
OPV00014*CD	August 2007	001	00610	Nitrogen, Ammonia (NH3)	1D Conc	1.5	15.24	8/20/2007
OPV00014*CD	August 2007	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1	17.145	8/1/2007
OPV00014*CD	August 2007	001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.09	.32339	8/6/2007
OPV00014*CD	August 2007	001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.09	.25871	8/20/2007
OPV00014*CD	August 2007	001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.06	.29105	8/1/2007
OPV00014*CD	August 2007	001	31616	Fecal Coliform	30D Conc	1000	5934.	8/1/2007
OPV00014*CD	August 2007	001	31616	Fecal Coliform	7D Conc	2000	5934.	8/1/2007
OPV00014*CD	August 2007	001	00300	Dissolved Oxygen	1D Conc	6	3.3	8/6/2007
OPV00014*CD	August 2007	001	00300	Dissolved Oxygen	1D Conc	6	4.3	8/20/2007

Attachment 2

Get New Data

Permit No.	Reporting Period	Station	Reporting Code	Parameter	Limit/Type	Limit	Reported Value	Violation Date
0PR00592*CD	October 2006	001	50060	Chlorine, Total Residu	1D Conc	.038	1.51	10/2/2006
0PR00592*CD	October 2006	001	50060	Chlorine, Total Residu	1D Conc	.038	.97	10/16/2006
0PR00592*CD	September 2008	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1	17.52	9/1/2008
0PR00592*CD	September 2008	001	00610	Nitrogen, Ammonia (NH3	7D Conc	1.5	17.52	9/1/2008
0PR00592*CD	September 2008	001	00610	Nitrogen, Ammonia (NH3	30D Qty	.02	.08342	9/1/2008
0PR00592*CD	September 2008	001	00610	Nitrogen, Ammonia (NH3	7D Qty	.03	.08342	9/1/2008
0PR00592*CD	September 2008	001	31616	Fecal Coliform	30D Conc	1000	7000.	9/1/2008
0PR00592*CD	September 2008	001	31616	Fecal Coliform	7D Conc	2000	7000.	9/1/2008
0PR00592*CD	September 2008	001	50060	Chlorine, Total Residu	1D Conc	.038	.05	9/15/2008
0PR00592*CD	September 2008	001	00300	Dissolved Oxygen	1D Conc	6	4.8	9/2/2008
0PR00592*CD	October 2008	001	50060	Chlorine, Total Residu	1D Conc	.038	.44	10/2/2008
0PR00592*CD	October 2008	001	50060	Chlorine, Total Residu	1D Conc	.038	.63	10/15/2008
0PR00592*CD	June 2008	001	00300	Dissolved Oxygen	1D Conc	6	4.9	6/3/2008
0PR00592*CD	July 2008	001	50060	Chlorine, Total Residu	1D Conc	.038	.38	7/2/2008
0PR00592*CD	July 2008	001	00300	Dissolved Oxygen	1D Conc	6	5.1	7/16/2008
0PR00592*CD	May 2008	001	31616	Fecal Coliform	30D Conc	1000	7000.	5/1/2008
0PR00592*CD	May 2008	001	31616	Fecal Coliform	7D Conc	2000	7000.	5/1/2008
0PR00592*CD	May 2008	001	50060	Chlorine, Total Residu	1D Conc	.038	.15	5/6/2008
0PR00592*CD	May 2008	001	50060	Chlorine, Total Residu	1D Conc	.038	.06	5/20/2008
0PR00592*CD	August 2008	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1	1.03	8/1/2008
0PR00592*CD	August 2008	001	31616	Fecal Coliform	30D Conc	1000	7000.	8/1/2008
0PR00592*CD	August 2008	001	31616	Fecal Coliform	7D Conc	2000	7000.	8/8/2008
0PR00592*CD	August 2008	001	00300	Dissolved Oxygen	1D Conc	6	5.9	8/25/2008
0PR00592*CD	May 2007	001	50060	Chlorine, Total Residu	1D Conc	.038	1.22	5/7/2007
0PR00592*CD	May 2007	001	50060	Chlorine, Total Residu	1D Conc	.038	.1	5/21/2007
0PR00592*CD	October 2007	001	31616	Fecal Coliform	30D Conc	1000	1500.	10/1/2007
0PR00592*CD	June 2007	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1	1.92	6/1/2007
0PR00592*CD	June 2007	001	00610	Nitrogen, Ammonia (NH3	7D Conc	1.5	1.92	6/1/2007
0PR00592*CD	June 2007	001	00300	Dissolved Oxygen	1D Conc	6	5.2	6/4/2007
0PR00592*CD	June 2007	001	00300	Dissolved Oxygen	1D Conc	6	5.7	6/18/2007
0PR00592*CD	July 2007	001	50060	Chlorine, Total Residu	1D Conc	.038	.32	7/2/2007
0PR00592*CD	July 2007	001	50060	Chlorine, Total Residu	1D Conc	.038	.07	7/16/2007
0PR00592*CD	July 2007	001	00300	Dissolved Oxygen	1D Conc	6	2.4	7/16/2007

OPR00592*CD	September 2007	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1	6.39	9/1/2007
OPR00592*CD	September 2007	001	00610	Nitrogen, Ammonia (NH3	7D Conc	1.5	6.39	9/1/2007
OPR00592*CD	September 2007	001	00610	Nitrogen, Ammonia (NH3	30D Qty	.02	.02419	9/1/2007
OPR00592*CD	September 2007	001	50060	Chlorine, Total Residu	1D Conc	.038	1.15	9/4/2007
OPR00592*CD	September 2007	001	50060	Chlorine, Total Residu	1D Conc	.038	.06	9/17/2007
OPR00592*CD	September 2007	001	00300	Dissolved Oxygen	1D Conc	6	4.3	9/4/2007
OPR00592*CD	August 2007	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1	2.9	8/1/2007
OPR00592*CD	August 2007	001	00610	Nitrogen, Ammonia (NH3	7D Conc	1.5	2.9	8/1/2007
OPR00592*CD	August 2007	001	50060	Chlorine, Total Residu	1D Conc	.038	1.05	8/6/2007
OPR00592*CD	August 2007	001	00300	Dissolved Oxygen	1D Conc	6	3.9	8/6/2007