



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

November 10, 2011

Mayor & Council  
Village of Clarksville  
P.O. Box 167  
Clarksville, Ohio

RE: Clarksville WWTW/Reconnaissance Inspection, NPDES Permit No. OH0127124/  
OEPA Permit No. 1PA000024\*BD and **Notice of Violation**

Ladies and Gentlemen:

On October 28, 2011 I conducted an NPDES Reconnaissance Inspection at the Village of Clarksville wastewater treatment works (WWTW). The final outfall and receiving stream were observed. The effluent was clear and there were no visible solids or foam. The required Outfall Sign was observed. A copy of the inspection report is enclosed.

A review of Clarksville's Discharge Monitoring Reports (DMRs) covering the months of November 2010 to September 2011 was performed. This review indicated a limit violation of the condition of your NPDES Permit. The specific instance of noncompliance is noted at the end of the inspection report.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your reports addressing the reasons for the above violations and the actions being taken to prevent further occurrences. No additional information is requested at this time. Future violations must continue to be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification".

If you have any questions, please contact me by phone at (937) 285-6028 or by e-mail at [michelle.waller@epa.state.oh.us](mailto:michelle.waller@epa.state.oh.us).

Respectfully,

Michelle Waller  
Division of Surface Water  
[michelle.waller@epa.state.oh.us](mailto:michelle.waller@epa.state.oh.us)



State of Ohio Environmental Protection Agency  
Southwest District Office

NPDES Compliance Inspection Report

Section A: National Data System Coding					
Permit #	NPDES#	Month/Day/Year	Inspection Type	Inspector	Facility Type
1PA00024*CD	OH0127124	10.28/2011	R	S	2

Section B: Facility Data		
Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Clarksville Wastewater Treatment Plant 160 Spring Hill Road Clarksville, Ohio 45113	11:45 AM	2/1/2011
	Exit Time	Permit Expiration Date
	12:00 PM	1/31/2016
Name(s) and Title(s) of On-Site Representatives	Phone Number(s)	
Name, Address and Title of Responsible Official	Phone Number	
Mayor & Council Village of Clarksville P.O. Box 167 Clarksville, Ohio 45113	(937) 289-2652	

Section C: Areas Evaluated During Inspection					
(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)					
N	Permit	N	Flow Measurement	N	Pretreatment
M	Records/Reports	N	Laboratory	N	Compliance Schedule
N	Operations & Maintenance	S	Effluent/Receiving Waters	N	Self-Monitoring Program
N	Facility Site Review	N	Sludge Storage/Disposal		Other
N	Collection System				

Section D: Summary of Findings (Attach additional sheets if necessary)	
See cover letter.	
Inspector	Reviewer
<i>Michelle Waller</i> Michelle Waller Division of Surface Water Southwest District Office	<i>Martyn Burt</i> Martyn Burt Compliance & Enforcement Supervisor Division of Surface Water Southwest District Office
11/10/11 Date	11/10/11 Date

**Notice of Violation**  
**Effluent Limit Violations (November 2010-September 2011)**

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
August 2011	E. coli	30D Conc	161	199	8/1/2011