



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

November 17, 2011

Mayor and Council  
Village of Williamsburg  
107 West Main Street  
Williamsburg, Ohio 45176

**Re: Williamsburg WWTP, NPDES Permit No. 1PB00034\*GD / OH0021571**

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of April 2011 through October 2011 for the referenced facility. Our review indicates that there were violations of the conditions of your NPDES permit for this time period. The specific instances of noncompliance were as follows:

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
April 2011	CBOD 5 day	7D Qty	56.8	57.9438	4/15/2011
April 2011	Total Suspended Solids	30D Qty	37.9	45.2339	4/1/2011
April 2011	Total Suspended Solids	7D Qty	56.8	118.485	4/15/2011
May 2011	CBOD 5 day	30D Qty	18.9	21.844	5/1/2011
May 2011	CBOD 5 day	7D Qty	28.4	64.3098	5/1/2011
May 2011	Nitrogen, Ammonia (NH3)	30D Qty	2.84	4.20825	5/1/2011
May 2011	Nitrogen, Ammonia (NH3)	7D Qty	4.35	12.7925	5/1/2011
May 2011	Phosphorus, Total (P)	30D Qty	3.79	3.79314	5/1/2011
May 2011	Total Suspended Solids	30D Qty	22.7	23.2125	5/1/2011
May 2011	Total Suspended Solids	7D Qty	34.1	76.2346	5/1/2011
June 2011	Nitrogen, Ammonia (NH3)	7D Conc	2.3	2.3165	6/8/2011
June 2011	Phosphorus, Total (P)	30D Conc	2.0	2.53	6/1/2011
July 2011	Nitrogen, Ammonia (NH3)	30D Conc	1.5	1.80388	7/1/2011
July 2011	Nitrogen, Ammonia (NH3)	30D Qty	2.84	3.18497	7/1/2011
July 2011	Nitrogen, Ammonia (NH3)	7D Conc	2.3	3.21	7/8/2011
July 2011	Phosphorus, Total (P)	30D Conc	2.0	2.21	7/1/2011
July 2011	Phosphorus, Total (P)	30D Qty	3.79	4.87671	7/1/2011

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
Aug. 2011	Phosphorus, Total (P)	30D Conc	2.0	2.66	8/1/2011
Aug.2011	Phosphorus, Total (P)	30D Qty	3.79	4.38969	8/1/2011
Sept. 2011	Nitrogen, Ammonia (NH3)	30D Conc	1.5	2.73113	9/1/2011
Sept. 2011	Nitrogen, Ammonia (NH3)	30D Qty	2.84	3.08047	9/1/2011
Sept. 2011	Nitrogen, Ammonia (NH3)	7D Conc	2.3	6.29	9/15/2011
Sept. 2011	Nitrogen, Ammonia (NH3)	7D Qty	4.35	6.61075	9/15/2011
Sept. 2011	Nitrogen, Ammonia (NH3)	7D Conc	2.3	2.91	9/22/2011
Oct. 2011	Nitrogen, Ammonia (NH3)	30D Conc	1.5	5.0625	10/1/2011
Oct. 2011	Nitrogen, Ammonia (NH3)	30D Qty	2.84	4.96005	10/1/2011
Oct. 2011	Nitrogen, Ammonia (NH3)	7D Conc	2.3	3.05	10/1/2011
Oct. 2011	Nitrogen, Ammonia (NH3)	7D Conc	2.3	4.05	10/8/2011
Oct. 2011	Nitrogen, Ammonia (NH3)	7D Conc	2.3	8.5	10/15/2011
Oct. 2011	Nitrogen, Ammonia (NH3)	7D Qty	4.35	8.58438	10/15/2011
Oct. 2011	Nitrogen, Ammonia (NH3)	7D Conc	2.3	4.65	10/22/2011
Oct. 2011	Nitrogen, Ammonia (NH3)	7D Qty	4.35	5.37962	10/22/2011
Oct. 2011	Phosphorus, Total (P)	30D Conc	2.0	2.07	10/1/2011

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, by December 16, 2011 as to the reason for the violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If you have any questions regarding the above, please contact me at this office.

Respectfully,



Ron Ware  
Division of Surface Water

cc: Clermont County General Health District

RWbp