



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

December 27, 2011

Jim Leslie
City of Harrison WWTP
10999 Campbell Road
Harrison, Ohio 45030

RE: Notice of Violation
Harrison WWTP
NPDES Permit 1PC00002*ID/OH0021440

Dear Mr. Leslie:

We have received your self-monitoring report for the month of November 2011, for the City of Harrison's Wastewater Treatment Plant. Our review indicates a violation of the conditions of the NPDES permit for the facility. The specific instance of noncompliance is as follows:

EFFLUENT LIMIT VIOLATION AT OUTFALL 001

Parameter	Limit Type	Limit	Reported Value	Violation Date
Total Suspended Solids	7D Conc	18	18.16	11/8/2011

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

I have reviewed your noncompliance notification letter that was received in this office on December 15, 2011. The letter did not specify a cause for the high level of TSS during the week of November 7, 2011. A response is required to this notice of violation discussing the investigation of the cause of the exceedance and any actions that were taken to alleviate the cause.

Jim Leslie
December 27, 2011
Page 2

Please submit your response by January 9, 2012. If you have any questions about this Notice of Violation letter, please call me at (937) 285-6101.

Sincerely,

A handwritten signature in black ink, appearing to read "Mary Osika", with a long horizontal flourish extending to the right.

Mary Osika
Environmental Specialist
Division of Surface Water

cc: Joel McGuire, City of Harrison
Bill Fischbein, Ohio EPA-Legal